

TECHNICAL SPECIFICATION FOR CENTRIFUGAL WATER PUMPING UNIT

1.0 Scope and Operating Conditions

- 3.1 The centrifugal pump shall deliver water with minimum operating pressure of 10 bar.
- 3.2 All pumps shall be tested for performance as per IS 1520 : 2007.

2.0 Electrical Motor Driver

- 3.3 The motor shall be a three phase induction motor rated for 415 V, 50 Hz power supply.

3.0 Material and Quality Requirements

- 3.4 The pump casing shall be constructed of cast iron.
- 3.5 The equipment shall carry valid ISI mark and BIS certification.