SOURCE_ID: DGMS-CIR-2023-12

TITLE: Safety Standards for Electrical Installations in Underground Coal Mines

SOURCE_TYPE: DGMS Circular

PAGE_COUNT: 8

PUBLICATION_DATE: 2023-11-20

SYNTHETIC: true

ISSUING_AUTHORITY: Directorate General of Mines Safety, Dhanbad

---

1. All electrical cables used underground must be flame-retardant.

2. Earth leakage relays must be installed at all substations and tested monthly.

3. Switchgears must have intrinsically safe circuits for control and interlock.

4. Clearances: A minimum clearance of 1.5 meters must be maintained around electrical panels.

5. Any electrical breakdown must be reported immediately to the electrical supervisor.