

MUNICIPAL PLAN SANCTION AUDIT REPORT

BBMP Building Plan Sanctioning & Compliance Engine | Report ID:
207bbf29-fc50-4086-8d86-1b031d1f58f8

STATUS VERDICT: CONDITIONAL_APPROVAL
CONDITIONAL SANCTION RECOMMENDED — Plan meets primary statutory standards but requires fulfillment of minor compliance conditions prior to permit issuance (score: 83.6/100).

Building Name:	Grethes hus	Readiness Score:	83.6 / 100
IFC File:	Grethes-hus-bok-2.ifc	Overall Risk:	HIGH
Ward / Zone:	Jayanagar (South Zone)	Authority:	BBMP
Generated At:	2026-07-29 06:49 UTC	Software Version:	0.1.0



Official Audit Verification QR Code
Scan to verify authentic digital signature and SHA256 checksum on municipal registry server.
SHA256: 2e28816b67e01be60eade1fe...

1. Executive Summary

Sanction Recommendation: GRANT CONDITIONAL SANCTION (Pending Compliance Fulfillment)

EXECUTIVE SANCTION SUMMARY | Report ID: 207bbf29-fc50-4086-8d86-1b031d1f58f8

Building: 'Grethes hus' (2bb286\$Af9iuq951kXeLke) | Type: Apartment | Ward: Jayanagar (South Zone).

Official Verdict: CONDITIONAL SANCTION RECOMMENDED — Plan meets primary statutory standards but requires fulfillment of minor compliance conditions prior to permit issuance (score: 83.6/100).

Readiness Score: 83.6/100 | Overall Risk Level: HIGH (Score: 18.0/100).

Evaluated Rules: 5 total (3 Passed, 1 Failed, 1 Warnings, 0 Blocking).

NOTICE: Plan meets structural safety criteria. Conditional permit may be issued upon submission of rectified drawings addressing minor non-blocking violations.

2. Building Summary

Property	Value	Property	Value
Building ID	2bb286\$Af9iuq951kXeLke	Plot Area	500.0 m²
Building Name	Grethes hus	Built-up Area	900.0 m²
Building Type	RESIDENTIAL	Height	3653.5 m
Occupancy	Residential	Floors	2
AI Classified Type	Apartment (96%)	FSI / Coverage	FSI: 1.80 90.0%

3. GIS Context & Spatial Analysis

Spatial Metric	Observation
BBMP Ward & Zone	Jayanagar (167) — South Zone
Masterplan Land Use	Residential
Nearest Road	Jayanagar 4th Block 9th Main Road (18.0 m wide)
Lake Distance & Buffer	5013 m (In Buffer: False)
Airport Zone & Height Limit	In Funnel: False Limit: Unlimited m
Flood Risk & Heritage Zone	Flood Risk: Low Heritage Zone: False

4. Compliance Summary

Overall Score	Rules Checked	Passed	Failed	Warnings	Blocking
60.0%	5	3	1	1	0

5. Rule Evaluation Table

Rule ID	Rule Name	Status	Severity	Clause
---------	-----------	--------	----------	--------

BBMP-FSI-001	Floor Space Index (FSI) Limit Check	PASSED	MAJOR	BBMP Bye-law 7.3.2
BBMP-COV-001	Ground Coverage Limit Check	FAILED	MAJOR	BBMP Bye-law 7.4.1
BBMP-HEIGHT-001	Building Height & High-Rise Threshold	WARNING	MINOR	BBMP Bye-law 8.1.1
BBMP-LAKE-001	Lake Buffer Zone Protection Check	PASSED	BLOCKING	KMC Act 1976 / NGT Buffer Directive
BBMP-AIRPORT-001	Airport Flight Funnel Height Restriction	PASSED	MAJOR	AAI NOC Regulations 2020

6. Prioritized Recommendations

[HIGH] BBMP-COV-001 (BBMP Bye-law 7.4.1): Reduce ground floor footprint coverage by 30.0% of plot area.
Reason: Ground coverage of 90.0% exceeds maximum limit of 60.0%. (Deviation: +30.0%).

[MEDIUM] BBMP-HEIGHT-001 (BBMP Bye-law 8.1.1): Obtain Fire Force NOC and install mandatory dual staircase emergency exits.
Reason: Building height of 3653.5 m classifies as high-rise (> 15.0 m); mandatory Fire Department NOC required. (Deviation: +3638.5 m).

7. Decision Summary & Action Plan

Top Risk Factors:

- [Compliance Violation Risk] 1 rule evaluation failure(s).
- [Structural & Dimensional Risk] High-rise structure (3653.5 m height > 15 m).
- [Structural & Dimensional Risk] High ground coverage (90.0% > 60%).

Next Officer Action Steps:

1. Issue Conditional Sanction Notice to applicant.
1. Require resubmission of rectified IFC model within 30 days.

8. Appendix — GIS Dataset Provenance

Dataset Name	Authority	License	Observation
BBMP Administrative Boundary	BBMP	Government Open Data	Point (12.925, 77.5938) evaluated against BBMP municipal boundary polygon
BBMP Ward Boundaries	BBMP / DataMeet	ODbL	Located in Ward 167 - Jayanagar
BBMP Zonal Classification	BBMP Corporation	Government Open Data	Mapped ward 'Jayanagar' (Ward 167) to BBMP South Zone
Greater Bangalore OSM Road Network	OpenStreetMap / BBMP GIS	ODbL	Nearest public road is Jayanagar 4th Block 9th Main Road (18.0m width) located 476.25m away
BDA Master Plan Land Use Classification	Bangalore Development Authority (BDA)	Government Official Master Plan	Site falls within Residential Zone (R1)

Bangalore Water Bodies & Storm Drains	BBMP Lake Development Authority / OSM	ODbL	Nearest lake 'Agara Lake' is 5012.66m away. Lake buffer violation: False. Storm drain distance: 2555.4m
Airport Height Restriction Funnel	Airports Authority of India (AAI)	Government Statutory Restriction	Site lies outside restricted airport approach funnels
Bangalore Flood & Topographic Vulnerability Model	BBMP Storm Water Drain (SWD) Department	Government Open Data	Flood risk evaluated as 'Low' based on drain distance (2555.4m) and lake distance (5012.66m)

9. Audit Metadata & Integrity Signatures

Report ID: 207bbf29-fc50-4086-8d86-1b031d1f58f8
SHA256 Payload Checksum: 2e28816b67e01be60eade1fea24726d34f7f50b3c645572cb8a6cfda6b265626
Generation Timestamp: 2026-07-29 06:49:20 UTC
Issuing System: MCRDSE Municipal Engine v0.1.0