

MUNICIPAL PLAN SANCTION AUDIT REPORT

BBMP Building Plan Sanctioning & Compliance Engine | Report ID:
36d0e0a1-248d-4727-a6a8-1f5547007121

STATUS VERDICT: APPROVED

PLAN SANCTION APPROVED — Building plan complies with all statutory regulations and municipal bye-laws (score: 99.5/100).

Building Name:	Jayanagar Residency	Readiness Score:	99.5 / 100
IFC File:	plan.ifc	Overall Risk:	LOW
Ward / Zone:	Jayanagar (South Zone)	Authority:	BBMP
Generated At:	2026-07-29 05:03 UTC	Software Version:	0.1.0



Official Audit Verification QR Code

Scan to verify authentic digital signature and SHA256 checksum on municipal registry server.
SHA256: 042c492f0e05d77c2cde72e0...

1. Executive Summary

Sanction Recommendation: GRANT BUILDING PERMIT SANCTION

EXECUTIVE SANCTION SUMMARY | Report ID: 36d0e0a1-248d-4727-a6a8-1f5547007121

Building: 'Jayanagar Residency' (BLD-PLAN-IFC-001) | Type: Residential | Ward: Jayanagar (South Zone).

Official Verdict: PLAN SANCTION APPROVED — Building plan complies with all statutory regulations and municipal bye-laws (score: 99.5/100).

Readiness Score: 99.5/100 | Overall Risk Level: LOW (Score: 0.0/100).

Evaluated Rules: 5 total (5 Passed, 0 Failed, 0 Warnings, 0 Blocking).

2. Building Summary

Property	Value	Property	Value
Building ID	BLD-PLAN-IFC-001	Plot Area	500.0 m²
Building Name	Jayanagar Residency	Built-up Area	900.0 m²
Building Type	RESIDENTIAL	Height	12.0 m
Occupancy	Residential	Floors	3
AI Classified Type	Residential (95%)	FSI / Coverage	FSI: 1.80 60.0%

3. GIS Context & Spatial Analysis

Spatial Metric	Observation
BBMP Ward & Zone	Jayanagar (167) — South Zone
Masterplan Land Use	Residential
Nearest Road	Jayanagar 4th Block 9th Main Road (18.0 m wide)
Lake Distance & Buffer	5013 m (In Buffer: False)
Airport Zone & Height Limit	In Funnel: False Limit: Unlimited m
Flood Risk & Heritage Zone	Flood Risk: Low Heritage Zone: False

4. Compliance Summary

Overall Score	Rules Checked	Passed	Failed	Warnings	Blocking
100.0%	5	5	0	0	0

5. Rule Evaluation Table

Rule ID	Rule Name	Status	Severity	Clause
BBMP-FSI-001	Floor Space Index (FSI) Limit Check	PASSED	MAJOR	BBMP Bye-law 7.3.2

BBMP-COV-001	Ground Coverage Limit Check	PASSED	MAJOR	BBMP Bye-law 7.4.1
BBMP-HEIGHT-001	Building Height & High-Rise Threshold	PASSED	MAJOR	BBMP Bye-law 8.1.1
BBMP-LAKE-001	Lake Buffer Zone Protection Check	PASSED	BLOCKING	KMC Act 1976 / NGT Buffer Directive
BBMP-AIRPORT-001	Airport Flight Funnel Height Restriction	PASSED	MAJOR	AAI NOC Regulations 2020

6. Prioritized Recommendations

✓ Zero compliance violations or corrective recommendations logged.

7. Decision Summary & Action Plan

Top Risk Factors:

- No critical risk factors identified.

Next Officer Action Steps:

1. Issue digital Sanction Certificate and approved plan blueprint.
1. Archive evidence bundle in municipal GIS registry.

8. Appendix — GIS Dataset Provenance

Dataset Name	Authority	License	Observation
BBMP Administrative Boundary	BBMP	Government Open Data	Point (12.925, 77.5938) evaluated against BBMP municipal boundary polygon
BBMP Ward Boundaries	BBMP / DataMeet	ODbL	Located in Ward 167 - Jayanagar
BBMP Zonal Classification	BBMP Corporation	Government Open Data	Mapped ward 'Jayanagar' (Ward 167) to BBMP South Zone
Greater Bangalore OSM Road Network	OpenStreetMap / BBMP GIS	ODbL	Nearest public road is Jayanagar 4th Block 9th Main Road (18.0m width) located 476.25m away
BDA Master Plan Land Use Classification	Bangalore Development Authority (BDA)	Government Official Master Plan	Site falls within Residential Zone (R1)
Bangalore Water Bodies & Storm Drains	BBMP Lake Development Authority / OSM	ODbL	Nearest lake 'Agara Lake' is 5012.66m away. Lake buffer violation: False. Storm drain distance: 2555.4m
Airport Height Restriction Funnel	Airports Authority of India (AAI)	Government Statutory Restriction	Site lies outside restricted airport approach funnels
Bangalore Flood & Topographic Vulnerability Model	BBMP Storm Water Drain (SWD) Department	Government Open Data	Flood risk evaluated as 'Low' based on drain distance (2555.4m) and lake distance (5012.66m)

9. Audit Metadata & Integrity Signatures

Report ID: 36d0e0a1-248d-4727-a6a8-1f5547007121

SHA256 Payload Checksum: 042c492f0e05d77c2cde72e076e9ecef0dc7720cec82c0ad03a3477636ae3166

Generation Timestamp: 2026-07-29 05:03:13 UTC

Issuing System: MCRDSE Municipal Engine v0.1.0