

MUNICIPAL PLAN SANCTION AUDIT REPORT

BBMP Building Plan Sanctioning & Compliance Engine | Report ID:
b5b84dbc-a701-4961-81e1-ab01fd19035c

STATUS VERDICT: REJECTED
SANCTION REFUSED — Building plan violates critical statutory bye-laws (1 blocking violation(s), score: 60.4/100).

Building Name:	MG Road Commercial Plaza	Readiness Score:	60.4 / 100
IFC File:	commercial_tower.ifc	Overall Risk:	CRITICAL
Ward / Zone:	Jayanagar (South Zone)	Authority:	BBMP
Generated At:	2026-07-29 09:56 UTC	Software Version:	0.1.0



Official Audit Verification QR Code
Scan to verify authentic digital signature and SHA256 checksum on municipal registry server.
SHA256: 633c97ecef2155c7046fe7d2...

1. Executive Summary

Sanction Recommendation: REFUSE PLAN SANCTION — MANDATORY REJECTION

EXECUTIVE SANCTION SUMMARY | Report ID: b5b84dbc-a701-4961-81e1-ab01fd19035c

Building: 'MG Road Commercial Plaza' (BLD-COMM-600) | Type: Commercial | Ward: Jayanagar (South Zone).

Official Verdict: SANCTION REFUSED — Building plan violates critical statutory bye-laws (1 blocking violation(s), score: 60.4/100).

Readiness Score: 60.4/100 | Overall Risk Level: CRITICAL (Score: 47.0/100).

Evaluated Rules: 5 total (2 Passed, 2 Failed, 1 Warnings, 1 Blocking).

CRITICAL NOTICE: Sanction must be refused in accordance with municipal statutory bye-laws due to blocking compliance violations or severe risk factors.

2. Building Summary

Property	Value	Property	Value
Building ID	BLD-COMM-600	Plot Area	500.0 m²
Building Name	MG Road Commercial Plaza	Built-up Area	3600.0 m²
Building Type	COMMERCIAL	Height	21.0 m
Occupancy	Commercial	Floors	6
AI Classified Type	Commercial (94%)	FSI / Coverage	FSI: 7.20 100.0%

3. GIS Context & Spatial Analysis

Spatial Metric	Observation
BBMP Ward & Zone	Jayanagar (167) — South Zone
Masterplan Land Use	Residential
Nearest Road	Jayanagar 4th Block 9th Main Road (18.0 m wide)
Lake Distance & Buffer	5013 m (In Buffer: False)
Airport Zone & Height Limit	In Funnel: False Limit: Unlimited m
Flood Risk & Heritage Zone	Flood Risk: Low Heritage Zone: False

4. Compliance Summary

Overall Score	Rules Checked	Passed	Failed	Warnings	Blocking
40.0%	5	2	2	1	1

5. Rule Evaluation Table

Rule ID	Rule Name	Status	Severity	Clause
---------	-----------	--------	----------	--------

BBMP-FSI-001	Floor Space Index (FSI) Limit Check	FAILED	BLOCKING	BBMP Bye-law 7.3.2
BBMP-COV-001	Ground Coverage Limit Check	FAILED	MAJOR	BBMP Bye-law 7.4.1
BBMP-HEIGHT-001	Building Height & High-Rise Threshold	WARNING	MINOR	BBMP Bye-law 8.1.1
BBMP-LAKE-001	Lake Buffer Zone Protection Check	PASSED	BLOCKING	KMC Act 1976 / NGT Buffer Directive
BBMP-AIRPORT-001	Airport Flight Funnel Height Restriction	PASSED	MAJOR	AAI NOC Regulations 2020

6. Prioritized Recommendations

[CRITICAL] BBMP-FSI-001 (BBMP Bye-law 7.3.2): Reduce total built-up area by 2475.0 m² to achieve FSI ≤ 2.25 .
Reason: FSI of 7.20 exceeds maximum permitted limit of 2.25 by 4.95. (Deviation: +4.95).

[HIGH] BBMP-COV-001 (BBMP Bye-law 7.4.1): Reduce ground floor footprint coverage by 40.0% of plot area.
Reason: Ground coverage of 100.0% exceeds maximum limit of 60.0%. (Deviation: +40.0%).

[MEDIUM] BBMP-HEIGHT-001 (BBMP Bye-law 8.1.1): Obtain Fire Force NOC and install mandatory dual staircase emergency exits.
Reason: Building height of 21.0 m classifies as high-rise (> 15.0 m); mandatory Fire Department NOC required. (Deviation: +6.0 m).

7. Decision Summary & Action Plan

Top Risk Factors:

- [Compliance Violation Risk] Presence of 1 BLOCKING violation(s).
- [Compliance Violation Risk] 2 rule evaluation failure(s).
- [Zoning & Spatial Risk] Building type (COMMERCIAL) differs from masterplan zone (Residential).
- [Structural & Dimensional Risk] High-rise structure (21.0 m height > 15 m).
- [Structural & Dimensional Risk] High FSI intensity (7.20 > 2.0).

Next Officer Action Steps:

1. Issue formal Rejection Order detailing statutory bye-law violations.
1. Notify applicant of appeal procedures under Municipal Act.

8. Appendix — GIS Dataset Provenance

Dataset Name	Authority	License	Observation
BBMP Administrative Boundary	BBMP	Government Open Data	Point (12.925, 77.5938) evaluated against BBMP municipal boundary polygon
BBMP Ward Boundaries	BBMP / DataMeet	ODbL	Located in Ward 167 - Jayanagar
BBMP Zonal Classification	BBMP Corporation	Government Open Data	Mapped ward 'Jayanagar' (Ward 167) to BBMP South Zone

Greater Bangalore OSM Road Network	OpenStreetMap / BBMP GIS	ODbL	Nearest public road is Jayanagar 4th Block 9th Main Road (18.0m width) located 476.25m away
BDA Master Plan Land Use Classification	Bangalore Development Authority (BDA)	Government Official Master Plan	Site falls within Residential Zone (R1)
Bangalore Water Bodies & Storm Drains	BBMP Lake Development Authority / OSM	ODbL	Nearest lake 'Agara Lake' is 5012.66m away. Lake buffer violation: False. Storm drain distance: 2555.4m
Airport Height Restriction Funnel	Airports Authority of India (AAI)	Government Statutory Restriction	Site lies outside restricted airport approach funnels
Bangalore Flood & Topographic Vulnerability Model	BBMP Storm Water Drain (SWD) Department	Government Open Data	Flood risk evaluated as 'Low' based on drain distance (2555.4m) and lake distance (5012.66m)

9. Audit Metadata & Integrity Signatures

Report ID: b5b84dbc-a701-4961-81e1-ab01fd19035c

SHA256 Payload Checksum: 633c97ecef2155c7046fe7d288e25f7c457ea084b3fa374e48b1c5c9fe1dcbf0

Generation Timestamp: 2026-07-29 09:56:19 UTC

Issuing System: MCRDSE Municipal Engine v0.1.0