

- NOTES**
1. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL RELEVANT ENGINEERS AND SPECIALISTS DRAWINGS & SPECIFICATIONS.
 2. ANY DISCREPANCIES BETWEEN THIS DRAWING AND ANY OTHER TO BE REPORTED TO THE ENGINEER IMMEDIATELY.
 3. ALL WORKS TO COMPLY WITH THE MOST CURRENT BRITISH STANDARDS.
 4. ALL DIMENSIONS IN MILLIMETERS UNLESS STATED OTHERWISE. NO DIMENSIONS ARE TO BE SCALED OFF THE DRAWING. USE FIGURED DIMENSIONS ONLY.
 5. ALL DIMENSIONS TO BE $\pm 3\text{mm}$ UNLESS SPECIFIED OTHERWISE.

- LEGEND**
- Isolator
 - Circuit Breaker
 - Switched Fuse

MVS1-INV1
INVERTER NUMBER
TRANSFORMER STATION NUMBER

Reference Drawings:
EP-EC006 -SLD-1 (General SLD)

Site Details:

	Model	Rating	Qty	Total Capacity
Modules	JAM72D45-620/LB	620Wp	80001 (total)	49.6MWp
			2963 string	
Inverter	SG350HX	352kVA	0	44MVA
			Modules Balanced	
TX Station	MVS3200	3520kVA	3	46.46MVA
	MVS4480	4928kVA	3	
	MVS6400	7040kVA	3	
Tilt & Pitch		15°		
Nominal Voltage at Connection Point		33kV ICP		
Export Capacity		40MW @0.95 PF		
Import Capacity		335 kVA		

1	SLD Updated			
	KN	NB	AH	24/03/2026
0	First Issued			
	KN	NB	AH	13/03/2026
REV	DESCRIPTION			
	DESIGNED	CHECKED	APPROVED	DATE



ETHICAL POWER LTD.
UNIT 9, DUNCHIDECK BARTON,
DUNCHIDECK, EXETER
EX2 9UA
(t) 01726 219618
www.ethical-power.com

Project:

EC006 - HESSAY

Title:

LVSLD

Drawing Status:

PRELIMINARY

Grid Ref (6 fig)

Site address: LOW MOORLANE,
YORK
YO268J

DWG No:	SHEET:	SCALE (A1):	REV:
EP-EC006-LVSLD-1	1 OF 1	NTS	00