



LECPL/AE5325/2026/Ahmednagar Bypass/ 1032

Dated: 05.06.2026

To,

The Authorized Signatory,

M/s Bharat Construction (India) Pvt. Ltd.,

9 PPCL Colony, Uday Vihar, Haridwar Bypass Dehradun,

Uttarakhand-248 001,

Email: bcipl.ddn@gmail.com, bcipl.shirdi@gmail.com

Sub: Balance work of Up-gradation to 4 Lane with Paved Shoulder configuration of the highway starting from existing km 88.400 (Savali Vihar) to km 163.400 (Start of Ahmednagar Bypass) (Design Length- 75.000km) section of NH-160 in the State of Maharashtra under Bharat Mala Pari yojana on EPC Mode- Source approval-Elastomeric Bearings (Ms. Polymer Products)

Ref:

1. EPC Contractor Letter no.- BCIPL/SITE/LECPL/AE/Ahilyanagar/2026-27/938 dated 02.05.2026
2. AE Letter no.- LECPL/AE5325/2026/Ahmednagar Bypass/936 Dated: 13.05.2026
3. EPC Contractor Letter no. BCIPL/SITE/LECPL/AE/Ahilyanagar/2026-27/1022 dated 27.05.2026

Dear Sir,

This is in reference to the above-mentioned letter wherein the EPC contractor has submitted the compliance to the observations raised by AE for the approval of Elastomeric Bearings (M/s Polymer Products) to this office for review.

The revised submission was reviewed by AE as per IRC Specification, MoRTH Guidelines and MoRTH circular and based on the above submission the material is approved based on following conditions-

1. The manufacturer shall comply with the requirements of the Contract Agreement, relevant IRC Codes, MoRTH Specifications, and applicable BIS Standards, including quality control and testing requirements.
2. Factory acceptance tests, as specified in relevant standards shall be conducted in the presence of the Authority Engineer or their authorized representative whenever required.
3. The contractor shall arrange third-party testing of Elastomeric Bearings upon the delivery of the consignment from a NABL-accredited laboratory.
4. Test certificates for each batch of elastomeric bearings shall be submitted prior to dispatch from the manufacturing facility.
5. The contractor shall ensure traceability of all bearings supplied to the project, including batch numbers, manufacturing dates, and corresponding test records.
6. Bearings shall be properly marked and identified as per relevant specifications to facilitate verification at site.
7. The approval shall remain valid only if the source maintains consistent quality standards and manufacturing practices. Any change in raw material source, manufacturing process, plant location, ownership, or quality control system shall be immediately brought to the notice of the Authority Engineer for review.
8. The contractor shall ensure proper handling, transportation, storage, and installation of bearings at site strictly in accordance with the manufacturer's recommendations and relevant specifications.
9. This approval does not absolve the contractor of its responsibility regarding the quality, performance, durability, and compliance of the supplied bearings with contract requirements.

