

Ref. No.: MML4-CA10-DBHL-RIFAST-LTR-2023-1357

Date: 23rd Feb 2023

To,

M/s. RINFRA-ASTALDI JV

3rd Floor, Building No. E7, MIDC X Road,
"B", Opposite MIDC Police Station,
Andheri East, Mumbai – 400 093.

Kind Attn: Mr. Lakshminarayan C. Bhat (Sr. Vice President)

Project: **Contract No.: MMRDA/4/MMRP/CA-08:** Part Design and Construction of elevated viaduct and 6 elevated stations viz. Bhakti Park Metro, Wadala TT, Anik Nagar Bus Depot, Suman Nagar, Siddharth Colony & Amar Mahal Junction [Excluding Architectural Finishing & Pre-engineered steel roof structure of Stations] from Chainage (-) 550 m to 5844.038 m of Line-4 Corridor [Wadala–Ghatkopar–Mulund–Thane–Kasarvadavali] of Mumbai Metro Rail Project of MMRDA.

Contract No.: MMRDA/4/MMRP/CA-10: Part Design and Construction of elevated viaduct and 6 elevated stations viz. Gandhi Nagar, Naval Housing, Bhandup Mahapalika, Bhandup Metro, Shangrila & Sonapur [Excluding Architectural Finishing & Pre-engineered steel roof structure of Stations] from Chainage 12250.746 M to 18935.299 M of Line-4 Corridor [Wadala–Ghatkopar–Mulund–Thane–Kasarvadavali] of Mumbai Metro Rail Project of MMRDA.

Contract No.: MMRDA/4/MMRP/CA-12: Part Design and Construction of Elevated Viaduct and 6 Elevated Stations viz. Kapurbawdi, Manpada, Tikuji-Ni-Wadi, Dongaripada, Vijay Garden and Kasarvadavali [Excluding Architectural Finishing & Pre-engineered steel roof structure of Stations] from Chainage 25036.251 M to Chainage 31872.088 M of Line 4 Corridor [Wadala–Ghatkopar–Mulund–Thane–Kasarvadavali] of Mumbai Metro Rail Project of MMRDA.

Subject: **Reply:** Submission of Profile of M/s. Polymer Products for POT/Elastomeric Bearing for the Metro Works

Ref.: 1. Contractor's Letter No.: RAJV/METRO/MMRDA/ML410/2022/0460 dated 13th Oct 2022

Dear Sir,

This is reference to your letter cited 1, through which you have requested to approve for the procurement of POT/Elastomeric Bearings from M/s. Polymer Products. We have reviewed and found that the above supplier is listed in RDSO's latest manufacturer as specified in Annexure-3, Technical Specification, Vol-4 of Contract Agreement. It is also noted that the RDSO has accord approval till Sept 2024, subject to further audit.

However, to evaluate the performance of bearings intended to be used in this project, the Engineer hereby instructs you to submit performance reports of the Elastomeric bearings of M/s. Polymer Products, that are being used elsewhere in metro projects and railways bridge projects.

These Elastomeric bearings shall be qualified and designed as per IRC:83 Part-II, EN 1337 Part 1 & Part III, and MORTH specifications.

The '**No objection**' shall be granted based on evaluation of all the required documents to be submitted by you.

All above mentioned is for your information and further necessary action.

Yours faithfully,
For **General Consultant "DBEC-HILL-LBG"**



Tan Boon Hoe
Project Director

CC: 1. Superintendent Engineer - Metro-PIU, MMRDA
2. M/s Milan Road Buildtech LLP (Mr. Ganesh Gholap)

VJ / PJ / FJC / SRM / YD / AM

