

Natural-Gas Heating System Removal

Permit and final inspection record for fossil-fuel space-heating removal associated with a heat-pump conversion.

PROPERTY

OWNER	Jordan Lee
ADDRESS	27 Cedar Ridge Road, Port Hardy, BC V0N 2P0
OCCUPANCY	Single detached dwelling

CONTRACTOR

COMPANY	MiniMe Contracting Company Mini Home Energy Solutions
ESP NUMBER	00001
REMOVAL DATE	July 24, 2026

APPROVED SCOPE AND OBSERVED COMPLETION

COMPONENT	REMOVAL / DISPOSITION	STATUS
Primary natural-gas forced-air furnace	Disconnected, removed from dwelling and transported for approved disposal/recycling.	Complete
Furnace vent connector and associated venting	Removed to termination point; remaining penetration sealed and weather-protected.	Complete
Dedicated heating-gas branch	Disconnected and capped by qualified gas fitter at the approved branch point. Leak test recorded.	Complete
Fossil-fuel backup heating	No natural-gas or propane backup space-heating appliance remains. New backup heat is electric.	None remains

FINAL INSPECTION RESULT - ACCEPTED

The primary fossil-fuel space-heating system and associated heating equipment were removed. The observed work is consistent with permit PH-MECH-26-0714 and the approved conversion scope. Natural gas is no longer used for space heating at this address.

INSPECTION RECORD

INSPECTION DATE	July 29, 2026 at 2:20 PM
INSPECTION ADDRESS	27 Cedar Ridge Road, Port Hardy, BC V0N 2P0
INSPECTOR	R. Campbell, Building & Mechanical Inspector
OUTCOME	Final accepted - no outstanding removal deficiencies

R. Campbell

July 29, 2026

Authority Having Jurisdiction representative

Final inspection date