

Bryant Central Ducted Heat Pump

Matched component package and efficiency data for the installation at 27 Cedar Ridge Road, Port Hardy, BC.



Variable-speed outdoor heat pump + matched indoor air handler

AHRI CERTIFIED REFERENCE NUMBER

203380999

This reference identifies the complete matched outdoor and indoor heat-pump combination shown below.

MATCHED COMPONENTS

COMPONENT	MANUFACTURER	MODEL	INSTALLATION ROLE
Outdoor heat-pump unit	Bryant	38MAQB18R--3	Variable-speed cold-climate outdoor unit
Indoor air handler	Bryant	FMC4Z1800AL	Matched central ducted indoor component; covered by product-list family FM(C,U)4Z18**AL*
Backup heat	Bryant-compatible	Electric auxiliary heat kit	Electric-only backup; no fossil-fuel backup

19.0

SEER

10.3

HSPF REGION IV

13,600

BTU/H AT -5 C

2.21

COP

QUALIFIED PRODUCT LIST RECORD

PRODUCT CATEGORY	Central ducted heat pump (Tier 2)
COMPRESSOR	Variable speed
COLD-CLIMATE RATED	Yes
CAPACITY MAINTENANCE	112%
ELIGIBILITY NOTE	Available to electrically heated customers and customers converting from fossil-fuel heating to a heat pump. Proof of fossil-fuel removal is required for a conversion.

INSTALLATION MATCH

Invoice MME-20260801-184 identifies Bryant outdoor unit 38MAQB18R--3, indoor air handler FMC4Z1800AL and AHRI reference 203380999. These are the components documented in this submittal.