



WETT RECOMMENDED INSPECTION CHECKLIST

Requested by: Lucy Hemphill	Inspection location: ☒ Same as requested or:
Address: 9460 Mayor's Way Port Hardy BC V0N2P0	Address:
Email: lucyhemphill7@gmail.com	Email:
Phone No.: 250 902 8257	Phone No.:
Inspector's name: Glen Boyd	WETT No.: 718
Reason(s) for inspection: System condition	
Level of inspection requested: ☐ Level 1 ☒ Level 2 ☐ Level 3	
Date of request: Jan 15 2026	Date of inspection: Jan 17 2026

Note: inspection results shown are what was present/noted at time of inspection.

This report documents findings at the time of the inspection. Compliance is referenced to currently published applicable codes and standards.



WETT RECOMMENDED INSPECTION CHECKLIST

FIREPLACE INSERT OR HEARTH-MOUNTED STOVE

Certification Standard: ☒ ULC S628 ☒ EPA ☐ CSA B415 ☐ Uncertified ☐ Unknown

Listing Agency: ☐ ULC ☐ CSA ☒ WH/ETL ☐ OTL ☐ Other: _____

Appliance Type: ☒ Fireplace Insert ☐ Hearth-mounted Stove ☐ Flue collar size: _____

Make: Pacific Energy **Model:** Pacific Insert **Serial #:** UTI

Installation manual available: ☒ Yes ☐ No

Installed by: Previous owner **Date:** _____ ☒ Unknown **Approx. Age:** 13 Years

Fireplace type: ☒ Masonry ☐ Masonry with heat form

☐ Factory-built: **Make:** _____ **Model:** _____ **Serial #:** _____

Chimney type: ☒ Masonry ☐ Factory-built

Appliance location: ☐ Basement ☒ Main Floor ☐ Other (specify): _____

Does the unit share a venting system with another appliance? ☐ Yes ☒ No

Inspection Results: Indicate inspection results for each component. Code compliance includes proper use of listed components. N/A = Not Applicable UTI = Unable To Inspect.

All non-compliance ratings should be considered for comment.

An inspection at any level can be expected to include some components marked UTI.

CLEARANCES	REQUIRED	ACTUAL(s)	CODE COMPLIANCE			
1. Combustible mantle	22 in	22 in	☐ N/A	☒ Yes	☐ No	☐ UTI
2. Top trim / facing	22 in	22 in	☐ N/A	☒ Yes	☐ No	☐ UTI
3. Side trim / facing	6.5 in	57 in	☐ N/A	☒ Yes	☐ No	☐ UTI
4. Combustible side wall	20.5 in	57 in	☐ N/A	☒ Yes	☐ No	☐ UTI
5. Ember pad material		Tile	☐ N/A	☒ Yes	☐ No	☐ UTI
6. Ember pad / left side	8 in	24 in	☐ N/A	☒ Yes	☐ No	☐ UTI
7. Ember pad / right side	8 in	24 in	☐ N/A	☒ Yes	☐ No	☐ UTI
8. Ember pad / front	18 in	47 in	☐ N/A	☒ Yes	☐ No	☐ UTI
9. Floor protection material		Tile	☐ N/A	☒ Yes	☐ No	☐ UTI

Fireplace Insert or Hearth-mounted Stove - page 2

10. Floor protection / left side		Tile	☐ N/A ☒ Yes ☐ No ☐ UTI
11. Floor protection / right side		Tile	☐ N/A ☒ Yes ☐ No ☐ UTI
12. Floor protection / front		Tile	☐ N/A ☒ Yes ☐ No ☐ UTI
13. Connection to stainless steel liner		Secure	☐ N/A ☒ Yes ☐ No ☐ UTI
14. Liner is continuous ☐ No ☒ Yes		Yes	☐ N/A ☒ Yes ☐ No ☐ UTI
15. Liner size Actual:		6 in	☐ N/A ☒ Yes ☐ No ☐ UTI
16. Liner cap ☐ No ☒ Yes		Yes	☐ N/A ☒ Yes ☐ No ☐ UTI
17.			
18.			
19.			
OTHER CONSIDERATIONS			
20. Fireplace modified ☐ No ☒ Yes			☐ N/A ☒ Yes ☐ No ☐ UTI
21. Outdoor air connection			☒ N/A ☐ Yes ☐ No ☐ UTI
22. Carbon monoxide alarm	Yes		
23. Smoke alarm	Yes		

Additional information:

Date: Jan 19 2026

File Reference #: 26-08

File reference No.: 26-08

Photos taken: ☒ Yes ☐ No

This checklist contains 4 pages in total. This report contains 7 pages in total.

Comments and Observations:

All non-compliance ratings should be considered for comment.

This fireplace insert and chimney liner installation complies with the manufacturer's installation instructions and current codes.

Please attach additional page(s) for this section.

<i>Customer Signature:</i>	<i>Inspector Signature:</i>  <i>Digital Signature:</i>
<i>Date:</i>	<i>Date:</i> Jan 19 2026







UNRELATED PERSONAL INFORMATION ADDED TO WETT REPORT

SYNTHETIC TEST DATA ONLY. The information below is deliberately unnecessary for this document and is included solely to test privacy flagging. All names, identifiers, contact details, and medical details are fictional.

Requester's date of birth	September 3, 1985
Government identification	BC driver's licence TEST-DL-000000
Personal health information	Fictional anxiety-treatment note
Personal banking details	Institution 000 / Transit 00000 / Account TEST-111111
Household children	Avery Example, age 6; Morgan Example, age 9
Unrelated third party	Neighbour Taylor Example, 12 Test Lane, 250-555-0142
Authentication secret	Password hint: TEST-ONLY-DO-NOT-USE

Expected test outcome: privacy review required; high-risk and unnecessary personal information detected.