

Harmonic Hunter

Power Quality Risk Report

Facility: Adyaan

Mode: Trend Risk Mode (Log Cadence) Generated: 2026-01-13 17:59


60 /100

Monitor

Baseline: 25/100 Δ +35
Overall risk increased from 25

Executive verdict

Early warning indicators detected. Continued monitoring is recommended to prevent escalation during peak demand or future expansion.



Key observations

- Phase A: High variability → harmonic risk signature

Why you're seeing this result

- Observed current behavior reflects non-linear electrical loading patterns.
- Phase-level variability suggests uneven load distribution across monitored circuits.

Recommended next steps

- Priority: Current variability indicates pulsed load behavior; schedule a power quality capture (true waveform) during peak load.

timeseries phase A

