

LIGHTING CONTROL SYSTEM







INTERIOR CREW LIGHTING




EXTERIOR LIGHTING



EXTERIOR SIGNAGE



BUILDING FACADE



— LINEAR LED FACADE LIGHTING

LIGHTING CONTROL NOTES:

LIGHTING CONTROL NOTES

- CONTACTOR DETAILS ARE DIAGRAMMATIC ONLY AND ARE SHOWN WITH TYPICAL LOADS AND CIRCUIT ASSIGNMENTS. LOADS, CIRCUIT ASSIGNMENTS AND NUMBER OF CONTACTORS MAY VARY BY RESTAURANT LOCATION AND PER EMS SUPPLIERS SYSTEMS. VERIFY EXACT REQUIREMENTS WITH EMS INSTALLATION DETAILS, SITE PLANS, ELECTRICAL PANEL SCHEDULES AND ACM. EC SHALL MAKE ALL MODIFICATIONS AS REQUIRED. FINAL INSTALLATION SHALL BE FULLY NEC AND ENERGY CODE COMPLIANT.
- ELECTRICAL CONTRACTOR SHALL FURNISH AND INSTALL ALL WIRING, CONNECTIONS, TERMINATIONS, ETC. THAT ARE NOT PROVIDED BY THE EMS SUPPLIER FOR A COMPLETE, FULLY OPERATIONAL AND CODE COMPLIANT LIGHTING CONTROL SYSTEM.
- ALL COMPONENTS FOR THIS LIGHTING CONTROL SYSTEM SHALL BE INSTALLED BY THE ELECTRICAL CONTRACTOR. SEE BOXED NOTE BELOW FOR OPTIONS.
- ALL COMPONENTS SHALL BE UL LISTED AND LABELED AND THE SYSTEM SHALL COMPLY WITH ALL LOCAL, STATE AND FEDERAL ENERGY CODE REQUIREMENTS.
- ALL CONTACTORS SHALL BE LOCATED IN A NEMA 1 ENCLOSURE WITH SCREW TYPE COVER MOUNTED DIRECTLY ABOVE LIGHTING PANEL OR SWITCHGEAR SO AS TO BE
- ALL CONTACTORS SHALL BE RATED FOR 30 AMP LOADS UNLESS NOTED OTHERWISE AND SHALL BE HID RATED WHERE REQUIRED.
- COIL VOLTAGES FOR ALL CONTACTORS SHALL BE 120 VOLT UNLESS NOTED

OTHERWISE.

LIGHTING CONTROL INSTALLATION OPTIONS

OPTION 1 CONTACTORS AND CONTACTOR ENCLOSURE FOR THIS LIGHTING CONTROL SYSTEM SHALL (STANDARD) BE FURNISHED BY THE EMS SUPPLIER AND INSTALLED BY THE ELECTRICAL CONTRACTOR ON SITE FOR A COMPLETE AND FULLY FUNCTIONAL SYSTEM.


OPTION 2 LIGHTING CONTROL CAN BE ACCOMPLISHED VIA UTILIZATION OF A SMART TYPE BREAKER PANEL REPLACING STANDARD PANEL LP-1. PANEL SHALL UTILIZE AN INTEGRAL MOTOR OPERATED CIRCUIT BREAKERS OR AN INTEGRAL CIRCUIT BREAKER/CONTACTOR TYPE COMBINATION DEVICE WITH AN INTEGRAL PROGRAMMING CONTROL MODULE AND SHALL BE ORDERED THROUGH OUR ELECTRICAL EQUIPMENT NATIONAL ACCOUNT PROGRAM (SIEMENS OR SQUARE-D) THROUGH OUR CONSTRUCTION PURCHASING TEAM.

BUILDING AUTOMATION SYSTEM NOTES

- BAS1. THE DIAGRAM SHOWN ABOVE IS SCHEMATIC IN NATURE AND SHOWS THE GENERAL REQUIREMENTS FOR THE INSTALLATION OF THE BUILDING AUTOMATION SYSTEM. EXACT EQUIPMENT REQUIREMENTS AND QUANTITIES WILL VARY PER SITE. G.C., M.C., T.C.C. AND E.C. SHALL COORDINATE ALL EXACT EQUIPMENT AND INSTALLATION REQUIREMENTS WITH SUPPLIER PRIOR TO SUBMITTING BID FOR A COMPLETE AND FULLY FUNCTIONAL
- BAS2. THE BUILDING AUTOMATION SYSTEM ALSO HAS ADDITIONAL OPTIONS AVAILABLE SUCH AS MONITORING DOOR CONTACTS (RESTROOM & COOLER FREEZER). ENERGY METER. COOLER/FREEZER TEMP. ADDITIONAL OPTIONS MAY BE SELECTED ON CENTRAL PURCHASING PROJECT DETAIL FORM. G.C., M.C., T.C.C. AND E.C. SHALL COORDINATE ALL EXACT INSTALLATION REQUIREMENTS WITH SUPPLIER PRIOR TO SUBMITTING BID FOR A COMPLETE AND FULLY FUNCTIONAL SYSTEM.
- ELECTRICAL CONTRACTOR SHALL FURNISH AND INSTALL ALL LINE AND LOW VOLTAGE WIRING AND CONNECTIONS, INCLUDING BUT NOT LIMITED TO CONTROL POWER TO ALL BAS COMPONENTS AND POWER CIRCUITRY WIRING OF ALL LIGHTING CONTACTORS. COORDINATE INSTALLATION WITH SITE SPECIFIC BAS INSTALLATION DETAILS PROVIDED BY SUPPLIER.

BUILDING AUTOMATION SYSTEM

INSTALLATION & TECHNICAL ASSISTANCE INFORMATION: LENNOX BAS: McD@CCBAC.com



PROVIDE AND INSTALL DATA OUTLET NEXT TO BAS PANEL, REMOTE COMMISSIONING IS NOT POSSIBLE WITHOUT DATA CONNECTION.

INSTALLATION NOTES:

1. PROVIDE, INSTALL AND SECURE ALL NECESSARY CABLE & CONDUIT PER BAS DRAWINGS AND SPECIFICATIONS. 2. MOUNT ALL BAS CONTROL ENCLOSURES.

3. PERFORM ALL LOW VOLTAGE TERMINATIONS.

4. ROUGH-IN, INSTALLATION AND WIRING FOR TEMPERATURE SENSORS AND TOUCHSCREEN PER PLAN LOCATIONS. 5. PROVIDE POWER CIRCUITS INTO CONTROL CANS PER BAS DETAILS.

6. COORDINATE WITH SUPPLIER TO SCHEDULE REMOTE COMMISSIONING. 7. CORRECT ALL PUNCH LIST ITEMS FOUND DURING REMOTE COMMISSIONING


CONTROLS SCHEDULE MARK DESCRIPTION MANUFACTURER MODEL **TEMPERATURE** *PROVIDED WITH BAS **AVERAGING** *PROVIDED WITH BAS ATS TEMPERATURE **HUMIDITY SENSOR** *PROVIDED WITH BAS

NOTES:

1. FOR TS, HS AND ATS LOCATIONS, REFER TO M1.2

WIRE LEGEND		
MARK	WIRE/CABLE TYPE	
	CAT 5E	
	18 AWG CONDUCTORS	

INSTALLATION & TECHNICAL ASSISTANCE INFORMATION: TRANE BAS: McDcontrols@Trane.com



PROVIDE AND INSTALL DATA OUTLET NEXT TO BAS PANEL. REMOTE COMMISSIONING IS NOT POSSIBLE WITHOUT DATA CONNECTION.

INSTALLATION NOTES:

1. PROVIDE, INSTALL AND SECURE ALL NECESSARY CABLE & CONDUIT PER BAS DRAWINGS AND SPECIFICATIONS. 2. MOUNT ALL BAS CONTROL ENCLOSURES.

3. PERFORM ALL LOW VOLTAGE TERMINATIONS. 4. ROUGH-IN, INSTALLATION AND WIRING FOR TEMPERATURE SENSORS AND TOUCHSCREEN PER PLAN LOCATIONS. 5. PROVIDE POWER CIRCUITS INTO CONTROL CANS PER BAS DETAILS.

6. COORDINATE WITH SUPPLIER TO SCHEDULE REMOTE COMMISSIONING. 7. CORRECT ALL PUNCH LIST ITEMS FOUND DURING REMOTE COMMISSIONING.

WIRE LEGEND	
MARK	WIRE/CABLE TYPE
	CAT 5E
	18 AWG CONDUCTORS

CONTROLS SCHEDULE

RTS TO BE MOUNTED IN RETURN AIR DUCT OF RTU

WIRELESS SPACE TEMPERATURE

SENSOR

TEMPERATURE

TEMP/HUMIDITY

FOR TS LOCATIONS, REFER TO M1.2

RTS


MANUFACTURER MODEL

*PROVIDED WITH BAS

*PROVIDED WITH BAS

FACTORY FURNISHED AND INSTALLED

W/EACH RTU



01/23/20

ced Ire the of

onald's McD

BB20

9

STANDARD

015-0071.00.0 LIGHTING CONTROLS