

TZ THT-03 Temperature and humidity transmitter

User Manual V1.1



1.Overview

The THT-03 temperature and humidity transmitter is designed based on the RS-485 communication interface, compatible with the standard Modbus-RTU protocol, and can be connected to the Modbus network to achieve temperature and humidity measurement and monitoring.

The THT-03 sensitive element uses SHT30, a newly designed CMOSens chip, an improved capacitive humidity sensor element and a standard energy gap temperature sensor element. Its performance has been greatly improved and even exceeded the previous generation of sensors (SHT1x and SHT7x).) Reliability level to make its performance in high humidity environments more stable.

THT-03 adopts the DIP switch to set the address method, which avoids the need to use the upper computer to set the address in advance, and is simple, convenient and easy to maintain and replace.

THT-03 adds a display screen and indicator lights, users can more intuitively see the current temperature and humidity data and machine status.

THT-03 has excellent long-term stability, low latency, low power consumption, strong resistance to chemical pollution and excellent repeatability. It is used for accurate temperature and relative measurement in HVAC, communication equipment rooms, warehouse buildings and automatic control applications. The ideal solution for humidity.

2.Feature

- Low power consumption
- Fully calibrated
- High precision and good consistency
- Long-term stability, low drift
- Humidity full range temperature compensation
- Standard Modbus-RTU protocol
- Strong interface defense capability and stable communication

3.Application field

Generally used in indoor clean environment, such as:

- HVAC
- Building automation
- Laboratory, hospital, library
- Storage and production facilities in the pharmaceutical, paper, food and electronics industries

4. Technical data

4.1 Power supply

| | |
|----------------|----------|
| Supply voltage | DC 5~36V |
| Current | 5mA |

4.2 Display and indicator

| | |
|-----------------|--|
| Display screen | Keep the power on, the screen will be bright, and the temperature and humidity display are accurate to one decimal place |
| Indicator light | Keep the power on, it will be red, and it will flash once when reading the data. |

4.3 Transfer Protocol

| | |
|-------------------|--------------------------------|
| Transfer Protocol | 485 port, standard modbus, rtu |
|-------------------|--------------------------------|

4.4 Transmission rate

| | |
|-------------------|-------------------|
| Transmission rate | 4800bps / 9600bps |
|-------------------|-------------------|

4.5 Transmission distance

The standard maximum transmission distance is about 1200 meters (depending on the use environment, transmission material and transmission rate)

| | |
|-----------------------------|----|
| Number of theoretical nodes | 32 |
|-----------------------------|----|

4.6 Temperature parameter

| | |
|----------------------|----------|
| Sensing element | SHT30 |
| Measuring range | -40~120℃ |
| Resolution | 0.1℃ |
| measurement accuracy | ±0.2℃ |

4.7 Humidity parameters

| | |
|----------------------|--|
| Sensing element | SHT3X |
| Working range | 0~95%RH |
| Resolution | 0.1%RH |
| Measurement Accuracy | ±2%RH |
| Hysteresis | < ±0.8%RH |
| Response time | About 8s (from 33%RH to 75%RH, in flowing air) |
| Long-term stability | <±0.25%RH/year (under no pollution) |


4.8 Environmental conditions

| | |
|---------------------|-----------------------------------|
| working environment | -40~85℃/ 0~100%RH(Non-condensing) |
| Storage environment | -40~85℃/ 0~100%RH(Non-condensing) |

4.9 Electrical connections

| Label | Function description |
|-------|--|
| B | Terminal B of RS485 interface |
| A | Terminal A of RS485 interface |
| GND | Public ground (connect to the negative end of the power supply when DC power is supplied) |
| VCC | Power supply positive (when DC power supply is connected to the positive terminal of the power supply) |

4.10 PC 机连接示意图




Note:
When setting up a RS485 network, pay attention to the RS485 grounding treatment to eliminate the common mode voltage. Suggest to connect the common ground of each sensor together, and then connect it to the ground wire of the RS-232/RS-485 transverter.
To connect, you can use the shielding layer of the shielded wire as the ground wire.

4.11 Temperature and humidity update time

| | |
|--------------------------------------|--|
| Temperature and humidity update time | Update temperature and humidity data every 30s |
|--------------------------------------|--|

5.DIP switch and address code



Note: The above picture is a schematic diagram of the DIP switch. The DIP switch has 8 DIP positions. The corresponding numbers from 1 to 8 are 128, 64, 32, 16, 8, 4, 2, 1, and these values are added together as the address code. As shown in the figure above, bits 1, 3, and 4 are in the ON position, so the address code is 128+32+16=176, that is, the address code is 176



First step



Second step

The above figure is a schematic diagram of the correct steps to open the DIP switch. The first step: use a screwdriver to unscrew the four corner screws in the figure, as shown in the figure above.

Step 2: Turn on the DIP switch to set the address, as shown in the second step above, the part circled on the left is the power communication interface. The connection method has been explained in the electrical connection in 4.9, please read it carefully

note! You can specify when ordering, and we will preset it for you.

6 Protocol

For the Modbus-RTU protocol, please refer to the relevant information, here is only a brief introduction.

6.1 Data frame format

| Start bit | Data bit | Parity bit | Stop bit |
|-----------|----------|------------|----------|
| 1 | 8 | 0 | 1 |

Note:

The above is the default format of the sensor. If you need other formats, please specify when ordering.

6.2 RTU message frame format

THT-02 follows the RTU information frame protocol. In order to ensure the integrity of the information frame, a pause time of 3.5 characters or more is required at the beginning and end of each information frame (T1-T2-T3-T4, this time can be based on the wave Calculated by special rate), each byte of the information frame needs to be transmitted continuously. If there is a pause time greater than 1.5 characters, the sensor will treat it as invalid information and will not respond.

6.3 Information frame format

| Start | address | function code | Data area | CRC check | end |
|-------------|---------|---------------|-----------|-----------|-------------|
| T1-T2-T3-T4 | 1byte | 1byte | N byte | 2byte | T1-T2-T3-T4 |

6.4 Register definition


| Register Address | Meaning | Description | Read and write |
|------------------|-------------------|---|--------------------|
| 0 | Temperature | The unit is 0.1 degree, MSB First, complement format, 7FFF H means the sensor is abnormal | Read only |
| 1 | Relative humidity | The unit is 0.1%, MSB First, complement format, 7FFF H means the sensor is abnormal | Read only |
| 2 | Reserved 1 | | Read only |
| 3 | Reserved 2 | | Read only |
| 4 | Address code | Set by DIP switch | Read only |
| 5 | Baud rate | Support 4800、9600 | Can read and write |
| 6 | Hardware version | | Read only |
| 7 | Software version | | Read only |

6.5 Address setting

You can specify when ordering, we will preset it for you, or you can modify it by yourself through the dial switch

6.6 Baud rate setting

You can specify when ordering, we will preset it for you, or you can modify it by yourself through the serial port assistant.



6.7 Host reads sensor information (function code 03)

The sensor allows the host to use the function code 03 to read the temperature and humidity measurement value of the sensor and other information. The information frame format of the 03 code is as follows:

Host request information frame

| Field Description | Example |
|-----------------------------|---------|
| Slave address | 01 |
| Function code | 03 |
| Register address high byte | 00 |
| Register address low byte | 00 |
| High byte of query quantity | 00 |
| Low byte of query quantity | 08 |
| CRC check code low byte | 44 |
| CRC check code high byte | 0C |

Sensor response information frame

| Field Description | Example |
|----------------------------|---------|
| Slave address | 01 |
| Function code | 03 |
| Return the number of bytes | 10 |
| Temperature data high byte | 00 |
| Temperature data low byte | FA |
| Humidity data high byte | 02 |
| Low byte of humidity data | 58 |
| 1 high byte reserved | 00 |
| 1 low byte reserved | 00 |
| 2 high byte reserved | 00 |
| 2 low byte reserved | 00 |
| Address code high byte | 00 |
| Address code low byte | 01 |
| Baud rate high byte | 25 |
| Baud rate low byte | 80 |
| Hardware version high byte | 06 |
| Hardware version low byte | 00 |
| Software version high byte | 00 |

| | |
|---------------------------|----|
| Software version low byte | 0A |
| CRC check code low byte | D4 |
| CRC check code high byte | 64 |

Data analysis

Temperature = 00FAH = $250 / 10 = 25.0^{\circ}\text{C}$;

Humidity = 0258H = $600 / 10 = 60.0\%\text{RH}$;

Reserved 1 = 0000H;

Reserved 2 = 0000H;

Address code = 0001H = 1;

Baud rate = 2580H = 9600;

Hardware version = 0600H;

Software version = 000AH = 10 = V1.0;

Note! If users only want to read the temperature and humidity or other registers, they only need to read the corresponding registers.

6.8 Host setting sensor information (function code 06)

This machine can currently set the baud rate (register address is 0005H), and the message frame format is as follows:

Host request information frame

| Field description | Example |
|----------------------------|---------|
| Slave address | 01 |
| Function code | 06 |
| Register address high byte | 00 |
| Register address low byte | 05 |
| Set value high byte | 25 |
| Set value low byte | 80 |
| CRC check code low byte | 82 |
| CRC check code high byte | FB |

Sensor response information frame

| Field description | Example |
|----------------------------|---------|
| Slave address | 01 |
| Function code | 06 |
| Register address high byte | 00 |
| Register address low byte | 05 |
| Set value high byte | 25 |
| Set value low byte | 80 |
| CRC check code low byte | 82 |
| CRC check code high byte | FB |

Data analysis: Set the baud rate to 9600

6.9 Abnormal response

When the host sends request information to the sensor, various errors may occur. At this time, the sensor sets the highest position of the function code to 1, and then returns an error code. The host can determine whether an error has occurred by detecting whether the highest bit of the function code is 1.

Return format

| Slave address | Function code | error code | CRC check |
|---------------|---------------|------------|-----------|
| 1 byte | 1 byte | 1 byte | 2 byte |

Error code

- 01: Illegal function code
- 02: Illegal data address
- 03: Illegal data value

6.10 CRC check code

RTU mode uses CRC-16 check, the check code occupies 2 bytes, if the check code is wrong, the sensor will ignore the host's request and not respond.

The calculation method of CRC-16 check code is as follows:

- ① Preset a 16-bit register as hexadecimal FFFF, call this register CRC register;
- ② XOR the first 8-bit binary data (the first byte of the information frame) with the lower 8 bits of the 16-bit CRC register, and place the result in the CRC register;
- ③ Shift the content of the CRC register one bit to the right (toward the low bit) and fill the highest bit with 0, check the right shift out position after shift;
- ④ If the shifted out bit is 0, repeat step ③ (shift one bit to the right again), if the shifted out bit is 1, the CRC register is XORed with the polynomial A001 (1010 0000 0000 0001);
- ⑤ Repeat steps ③ and ④ until the right shift is 8 times, so that the entire 8-bit data has been processed;
- ⑥ Repeat steps ② to step ⑤ to process the next byte of the message frame;
- ⑦ After calculating all the bytes of the information frame according to the above steps, the content of the CRC register obtained is: 16-bit CRC check code.

7 Dimensions (unit: mm)

