



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK

Sub Divisional Water Quality Chemical Testing Laboratory, Kanakapura

2nd Floor, Taluku Adalitha Soudha (Mini Vidhana Soudha)

Bangalore South District, Karnataka-562117

TEST REPORT					
Address of the sampling location: ST.Michel's English School Mysore Main Road Kanakapura -562117				Report date: 23/06/2026	
				Report Number:0012	
				Reference: Sample receipt form	
				Sample receipt date: 19/06/2026	
				Sample code: KAN26JUN0014	
				Date of Sample collection:19/06/2026	
				Analysis started date: 20/06/2026	
				Analysis completion date:23/06/2026	
Sample collection protocol: APHA 24 TH Edition 2023				Sample quantity: 1 Litr.	
Sample Particulars : WPP					
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colorless clear liquid					
1	pH Value @ 25 °C	7.91	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu S/c$ @25 °C	68.6	—	—	IS 3025 (Part-14) : 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2023
5	Colour, Hazen Units	<1.0	5	15	IS 3025 (Part-4) :2021
6	Turbidity, NTU	<0.5	1	5	IS 3025 (Part-10) : 2023
7	Total Dissolved Solids@ 180°C, mg/l	32.6	500	2000	IS 3025 (Part-16) : 2023
8	Alkalinity as CaCO ₃ , mg/l	24.2	200	600	IS 3025 (Part-23) : 2023
9	Total Hardness as CaCO ₃ , mg/l	31.3	200	600	IS 3025 (Part-21) : 2009
10	Calcium as Ca, mg/l	6.4	75	200	IS 3025 (Part-40) : 1991
11	Magnesium as Mg, mg/l	9.5	30	100	IS 3025 (Part-46) : 2023
12	Chloride as Cl, mg/l	29.7	250	1000	IS 3025 (Part-32) : 1988
13	Sulphate as SO ₄ , mg/l	2.1	200	400	IS 3025 (Part-24) : 2022
14	Fluoride as F, mg/l	0.4	1	1.5	APHA 23 rd Edition 4500-FD
15	Nitrate as NO ₃ , mg/l	5.2	45	No relaxation	APHA 23 rd Edition 4500- NO ₃ D
16	Iron as Fe, mg/l	<0.1	1	No relaxation	IS 3025 (Part-53) : 2003
17	Residual Chlorine as RFC, mg/l	<0.1	0.2	1.0	APHA 23 rd Edition 4500-Cl F
Remarks: The given sample meets the IS10500:2012 requirement for the above tested parameters.					
 Analysed By Analyst		RDWSD Water Quality Lab Kanakapura.			
Verified By Assistant Executive Engineer Rural Water Supply & Sanitation Sub-Division Kanakapura					

RDWSD/WQMSP/TeR/01 Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation. Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

Assistant Executive Engineer
 Rural Water Supply & Sanitation Sub-Division
 Kanakapura