

**SCALE 40**  
**CHANGING/LOCKER ROOMS**

1 This scale is to be read in conjunction with Scale 1. Changing rooms and locker facilities may be provided for those living out personnel who are required by local regulations to change from their normal working dress when leaving the unit/station, and for all those personnel who need to change into some form of protective or alternative clothing at their place of work.

2 The areas specified per person in Serial 21 include space for the locker and for changing, and, for personnel on ceremonial public duties, a 400mm drying cabinet. The

size and quantity of lockers (DAS items) will be determined in accordance with JSP 308 Scale JS/108.

3 When these facilities are required at more than one location within a unit/station, the overall provision is not to exceed that stated in Serial 21. However, a minimum of 1 WC, 1 washhand basin and 1 shower should be provided in each location. If sited adjacent to living accommodation, separate external access is to be provided.

4-20 Spare.

# CHANGING/LOCKER ROOMS (contd)

JSP 315

Accommodation	Area per locker	M & E Services	Planning Notes, Special Fittings, etc.
(a)	(b)	(c)	(d)
21 Changing/ Locker Room	<p>0.8m<sup>2</sup> up to 300mm wide approx. locker</p> <p>1.2m<sup>2</sup> up to 500mm wide approx. locker</p> <p>1.6m<sup>2</sup> over 500mm wide approx. locker</p> <p>2.5m<sup>2</sup> per 600mm wide approx. locker with 400mm drying cabinet and equipment preparation facilities. (for ceremonial troops)</p> <p>Minimum room size - 4.5m<sup>2</sup></p>	<p><b>Illumination</b> - 175 lux</p> <p><b>Heating</b> - 16.0°C.</p>	<p>Separate rooms for males and females. Planned adjacent, and with direct access, to the respective toilet areas.</p> <p>Self closing doors.</p> <p>Built-in bench seating as required. Clothes hooks one per person.</p> <p>Where personnel are engaged on outdoor duties, a drying cupboard may be provided (0.1m<sup>2</sup> per person).</p>

**CHANGING/LOCKER ROOMS (contd)****JSP 315**

(a)	(b)	(c)	(d)
22 Toilet Area	Provision based on number of personnel for whom lockers are provided		Refer to Scale 1 Annex B. Self closing connecting door to locker room.
Showers for each sex to the following scale	3.0m <sup>2</sup> per shower cubicle		To be segregated from WC area. One fixed seat, 2 clothes hooks, soap holder, shelf and towel rail to each shower. Showers are to be separately partitioned, with curtain rails.
Up to 50	1		
51 - 150	2		
151 - 250	3		
251 - 350	4		

\*\*\*\*\*