

JSP 315 ACCOMMODATION SCALES

SCALE 55 RESPIRATOR TESTING FACILITY

JSP 315 SCALE 55 RECORD OF AMENDMENTS

(DIO SEC POLICY)

Please check references – some Serial Numbers have changed since April 2012

AMEND NO	DATE	MINOR/REWRITE
1	APR 2012	REWRITE
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		

AMENDED APRIL 2012

SCALE 55

RESPIRATOR TESTING FACILITY

- 01 This scale is to be read in conjunction with Scale 1.
- 02 A Respirator Testing Facility (RTF) may be provided as follows:
- a Initial Training Establishments
 - b Defence Chemical Biological Radiological and Nuclear (CBRN) Compounds in nominated Training Centres.
- 03 Where a respirator testing facility is not justified a suitable room or tent can be used as provided for in the Joint Manual of NBC Defence, Joint Warfare Publication 3-61.1.1 Part 3 Respirator Test Facility; Para 1007.
- 04 A standard Drawing RTC 55746/1 is available from DIO, but has not been updated recently and should be checked to ensure that it complies with current Building Regulations, British Standards, Health and Safety Regulations, COSHH Regulations, etc.
- 05 The facility detailed in the drawing is only suitable for use when the RTF is to be situated more than 100m from any occupied buildings, roads or boundaries, which is the ideal situation. Where this is not possible, a ventilation system, with HEPA filtration on the extract, should be provided to allow a purge of the facility after respirator testing.
