

1 Synchronization of KABA Offline Components

1.1 Overview

The initialization of Kaba offline components (digital cylinders and electronic door mounts) and the synchronization of specific configurations (e.g. access time models and public holidays) are implemented via the Kaba Programmer 1460, which is loaded via the Kaba B-COMM software.

An interface between HYDRA and the B-COMM server automatically synchronizes accesses configured in HYDRA and other access configurations with Kaba B-COMM.

1.2 Configuration of the interface

The technical settings and configurations regarding the interface connection to the B-COMM server are described in a separate document on the [installation](#) of the CardLink function.

1.3 Initiation and process of synchronization

The synchronization of the B-COMM offline components is initiated directly and automatically upon the modification of master data in HYDRA Access Control. Every time, the complete administration area with all sub-elements is synchronized. The following modifications to master data will initiate a synchronization:

- Accesses
- Access groups
- Opening hours
- Access time models
- Access periods
- Public holidays

Since only one synchronization can run at a time, modifications which are made at virtually the same time at various clients in HYDRA will be transferred to the B-COMM server one after the other. This may result in minor synchronization delays.

1.4 Logging

Synchronization runs are recorded in the HYDRA system logs. They are identifiable as BCOMM application. The system logs must be checked regularly for errors.

All started synchronization runs are recorded in the log file `err\zksoffline.pro` of the HYDRA server. This file also indicates when several interface calls are serialized due to the simultaneous modification of master data at different HYDRA clients.

1.5 Access log

The access logs can be read from the offline components by means of the Kaba Programmer and evaluated in B-COMM.

An interface transferring the access logs from B-COMM to HYDRA does not exist.