

Manual

OPC Server for Siemens Controls OPC-SSS 8.1

Version 1.0.23049

Last changed on: 02.09.2020

Copyright

©Copyright 2020 All rights reserved.

SAP® and R/3® are registered trademarks of SAP AG.

WINDOWS® is a registered trademark of Microsoft Corporation.

MPDV® and HYDRA® are registered trademarks of MPDV Mikrolab GmbH.

ORACLE® is a registered trademark of ORACLE Corporation, California, USA.

Copying and distribution of this documentation or any part thereof, for any purpose or in any form, is prohibited without prior written permission from MPDV Mikrolab GmbH.

The information contained in this documentation is subject to change without prior notice.

Contents

1	Overview OPC Server for Siemens Controls	4
---	--	---

1 Overview OPC Server for Siemens Controls

Overview

In the world of automation the OPC standard has spread more and more and is still advancing to establish a direct communication with machines. For further information on OPC (OLE for Process Control), please refer to the respective documentation or the website of the OPC foundation <http://www.opcfoundation.org>.

Purpose

HYDRA provides an OPC server to connect Siemens controls to the HYDRA system.

This OPC server reads out the data fields of the Siemens control and provides the OPC client with it.

This approach can be used for data from the following HYDRA modules:

- MDE - Machine Data Collection (counters/meters, cycle, status)
- PDV - Process Data Collection (process values)
- DNC - Direct Numerical Control (setting values)
- Scale values

Implementation notes

In general, communication is based on the exchange of data using defined variables in the OPC server. The variable contents of machines are provided as labeled data points/OPC items in the OPC server. The OPC client connects application programs with these variables. Thus, read and write accesses to OPC items are made available for application programs in a specific and transparent way. The OPC-DA specification in version 2.0 defines the data transport. For further details on which data points can be provided by a specific control, please refer to the corresponding documentation about the control in question.

Integration

The OPC server is installed on a data acquisition PC and/or terminal (Windows).

Please note: Further components might be required if used with a control by Siemens, (e.g. communication module).

Functions

Configurable OPC server to communicate with S5/S7 controls transferring OPC variables, e.g. machine statuses, process data and meter readings.