


AGRID

Fan Coil Thermostat — AGR25-01

Wiring Diagrams

Full manual: a-grid.com/docs/thermostat/agr25-01

Support: support@a-grid.com



a-grid.com

Terminal Block Overview

AGRID AGR25-01

Terminal Block

	N	Neutral
	L	Phase
	RL1	Relay 1
	RL2	Relay 2
	RL3	Relay 3
	RL4	Relay 4
	RL5	Relay 5
	G	0V Reference
	DAC1	0-10V Out 1
	DAC2	0-10V Out 2
	DAC3	0-10V Out 3
	B	Reserved
	A	Reserved
	S1	Sensor In 1
	S2	Sensor In 2

LOW VOLTAGE ZONE (230V~)

N — Neutral conductor

L — Phase conductor

RL1-RL5 — SPST-NO relay outputs
Max 5A (Ind.) 220-240V~

EXTRA-LOW VOLTAGE ZONE (0-10V)

G — 0V reference

DAC1-DAC3 — 0-10V analog outputs

S1, S2 — External sensor inputs

B, A — Reserved (do not connect)

WIRING SPECS

LLV wires 230V~ (N, L, RL1-5)

1.5 mm²

ELV wires 0-10V (G, DAC1-DAC3, S1, S2)

0.5-0.75 mm²

Max DAC cable length

20 m

Max sensor cable length

20 m

Wire type

Solid or crimped stranded

Shielded cable

Recommended > 10 m

 Galvanic isolation between LV zone 230V~ (N, L, RL1-RL5) and ELV zone (G, DAC1-DAC3, S1, S2)

Legend & Conventions

AGRID AGR25-01

OUTPUT ABBREVIATIONS

FH	Fan High Speed
FM	Fan Medium Speed
FL	Fan Low Speed
HV	Hot Valve (Heating)
CV	Cold Valve (Cooling)
HR	Power contactor of Electric Heater (Resistance)
Fan	Fan (0-10V proportional)
N/S	Not Supported



SAFETY WARNINGS

- Installation by qualified electrician only
- Disconnect power before wiring
- All-pole disconnection device required (min 3mm gap)
- Relay outputs = control signals only
- For electric heaters: use external power contactor
- B and A terminals: do NOT connect

CONTROL TYPES

ON/OFF (Relay)

Via relay outputs RL1-RL5. Including 3-speed fan mode (3 relays, one per speed).

0-10V (Proportional)

Via DAC outputs DAC1-DAC3. Proportional analog signal for modulating actuators.

EQUIPMENTS



Fan 0 - 10V

Fan 3 Speeds: FH = Fan High | FM = Fan Medium | FL = Fan Low



HV = Heat Valve

CV = Cool Valve



HR = Heating Resistance

(through an external power contactor)

List of configurations - No valves

Without valve

# ↗	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
1 	Fan Only	3-speed	x	x	RL1=FH, RL2=FM, RL3=FL	OK
2 	Fan Only	0-10V	x	x	DAC3=Fan	OK

Without valve + Electric Heater

# ↗	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
3 	Fan Only + Electric Heater	3-speed	x	ON/OFF	RL1=FH, RL2=FM, RL3=FL, RL5=HR	OK
4 	Fan Only + Electric Heater	0-10V	x	ON/OFF	DAC3=Fan, RL5=HR	OK

 **HR (electric heater) must NEVER be directly switched by relay. Use an external power contactor.**

List of configurations - 2 pipes / 2 pipes + 2 wires

AGRID AGR25-01

2-pipe mixed - heat only - cool only (2T)

# ↗	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
5 	2T: Fan + 1 Valve	3-speed	ON/OFF	x	RL1=FH, RL2=FM, RL3=FL, RL4=HV	OK
6 	2T: Fan + 1 Valve	3-speed	0-10V	x	RL1=FH, RL2=FM, RL3=FL, DAC1=HV	OK
7 	2T: Fan + 1 Valve	0-10V	ON/OFF	x	DAC3=Fan, RL4=HV	OK
8 	2T: Fan + 1 Valve	0-10V	0-10V	x	DAC1=HV, DAC3=Fan	OK

2-pipe (mixed - heat only - cool only) + Electric Heater (2T + 2 wires)

# ↗	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
9 	2T + 2 wires: Fan + 1 Valve + Heater	3-speed	ON/OFF	ON/OFF	RL1=FH, RL2=FM, RL3=FL, RL4=HV, RL5=HR	OK
10 	2T + 2 wires: Fan + 1 Valve + Heater	3-speed	0-10V	ON/OFF	RL1=FH, RL2=FM, RL3=FL, DAC1=HV, RL5=HR	OK
11 	2T + 2 wires: Fan + 1 Valve + Heater	0-10V	ON/OFF	ON/OFF	DAC3=Fan, RL4=HV, RL5=HR	OK
12 	2T + 2 wires: Fan + 1 Valve + Heater	0-10V	0-10V	ON/OFF	DAC1=HV, DAC3=Fan, RL5=HR	OK

 **HR (electric heater) must NEVER be directly switched by relay. Use an external power contactor.**

List of configurations - 4 pipes

AGRID AGR25-01

4-pipe (4T)

# ↗	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
13 	4T: Fan + 2 Valves	3-speed	ON/OFF	x	RL1=FH, RL2=FM, RL3=FL, RL4=HV, RL5=CV	OK
14 	4T: Fan + 2 Valves	3-speed	0-10V	x	RL1=FH, RL2=FM, RL3=FL, DAC1=HV, DAC2=CV	OK
15 	4T: Fan + 2 Valves	0-10V	ON/OFF	x	DAC3=Fan, RL4=HV, RL5=CV	OK
16 	4T: Fan + 2 Valves	0-10V	0-10V	x	DAC1=HV, DAC2=CV, DAC3=Fan	OK

4-pipe + Electric Heater (4T + 2 wires)

# ↗	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
17 	4T + 2 wires: Fan + 2 Valves + Heater	3-speed	0-10V	ON/OFF	RL1=FH, RL2=FM, RL3=FL, DAC1=HV, DAC2=CV, RL5=HR	OK
18 	4T + 2 wires: Fan + 2 Valves + Heater	0-10V	ON/OFF	ON/OFF	DAC3=Fan, RL4=HV, RL5=CV, RL3=HR	OK
19 	4T + 2 wires: Fan + 2 Valves + Heater	0-10V	0-10V	ON/OFF	DAC1=HV, DAC2=CV, DAC3=Fan, RL5=HR	OK
20 	4T + 2 wires: Fan + 2 Valves + Heater	3-speed	ON/OFF	ON/OFF	x	N/S (Not enough relays)


 **HR (electric heater) must NEVER be directly switched by relay. Use an external power contactor.**

Detailed wiring schematics

Fan Coil Thermostat — AGR25-01

Configuration #1


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
1	Fan Only	3-speed	x	x	RL1=FM, RL2=FM, RL3=FL	OK



Configuration #2


AGRID AGR25-01

#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
2	Fan Only	0-10V	x	x	DAC3=Fan	OK



Configuration #3


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
3	Fan Only + Electric Heater	3-speed	x	ON/OFF	RL1=FM, RL2=FL, RL3=FL, RL5=HR	OK



⚠ HR (electric heater) must NEVER be directly switched by relay. Use an external power contactor.

Configuration #4


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
4	Fan Only + Electric Heater	0-10V	x	ON/OFF	DAC3=Fan, RL5=HR	OK



⚠ HR (electric heater) must NEVER be directly switched by relay. Use an external power contactor.

Configuration #5


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
5	2T: Fan + 1 Valve	3-speed	ON/OFF	x	RL1=FM, RL2=FL, RL3=FL, RL4=HV	OK



Configuration #6

AGRID AGR25-01


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
6	2T: Fan + 1 Valve	3-speed	0-10V	x	RL1=FH, RL2=FM, RL3=FL, DAC1=HV	OK



Configuration #7

AGRID AGR25-01


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
7	2T: Fan + 1 Valve	0-10V	ON/OFF	x	DAC3=Fan, RL4=HV	OK



Configuration #8

AGRID AGR25-01


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
8	2T: Fan + 1 Valve	0-10V	0-10V	x	DAC1=HV, DAC3=Fan	OK



Configuration #9

AGRID AGR25-01


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
9	2T + 2 wires: Fan + 1 Valve + Heater	3-speed	ON/OFF	ON/OFF	RL1=FH, RL2=FM, RL3=FL, RL4=HV, RL5=HR	OK



⚠ HR (electric heater) must NEVER be directly switched by relay. Use an external power contactor.

Configuration #10

#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
10	2T + 2 wires: Fan + 1 Valve + Heater	3-speed	0-10V	ON/OFF	RL1=FM, RL2=FL, RL3=FL, DAC1=HV, RL5=HR	OK




⚠ HR (electric heater) must NEVER be directly switched by relay. Use an external power contactor.

Configuration #11

AGRID AGR25-01


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
11	2T + 2 wires: Fan + 1 Valve + Heater	0-10V	ON/OFF	ON/OFF	DAC3=Fan, RL4=HV, RL5=HR	OK



⚠ HR (electric heater) must NEVER be directly switched by relay. Use an external power contactor.

Configuration #12


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
12	2T + 2 wires: Fan + 1 Valve + Heater	0-10V	0-10V	ON/OFF	DAC1=HV, DAC3=Fan, RL5=HR	OK



⚠ HR (electric heater) must NEVER be directly switched by relay. Use an external power contactor.

Configuration #13


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
13	4T: Fan + 2 Valves	3-speed	ON/OFF	x	RL1=FM, RL2=FL, RL3=FL, RL4=HV, RL5=CV	OK



Configuration #14

AGRID AGR25-01


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
14	4T: Fan + 2 Valves	3-speed	0-10V	x	RL1=FH, RL2=FM, RL3=FL, DAC1=HV, DAC2=CV	OK



Configuration #15


AGRID AGR25-01

#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
15	4T: Fan + 2 Valves	0-10V	ON/OFF	x	DAC3=Fan, RL4=HV, RL5=CV	OK




Configuration #16

#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
16	4T: Fan + 2 Valves	0-10V	0-10V	x	DAC1=HV, DAC2=CV, DAC3=Fan	OK



Configuration #17


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
17	4T + 2 wires: Fan + 2 Valves + Heater	3-speed	0-10V	ON/OFF	RL1=FH, RL2=FM, RL3=FL, DAC1=HV, DAC2=CV, RL5=HR	OK



⚠ HR (electric heater) must NEVER be directly switched by relay. Use an external power contactor.

Configuration #18


#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
18	4T + 2 wires: Fan + 2 Valves + Heater	0-10V	ON/OFF	ON/OFF	DAC3=Fan, RL4=HV, RL5=CV, RL3=HR	OK



⚠ HR (electric heater) must NEVER be directly switched by relay. Use an external power contactor.

Configuration #19

#	Configuration	Fan Regulation Type	Valves Regulation Type	Electric Heater Regulation Type	Output Assignment	Status
19	4T + 2 wires: Fan + 2 Valves + Heater	0-10V	0-10V	ON/OFF	DAC1=HV, DAC2=CV, DAC3=Fan, RL5=HR	OK



⚠ HR (electric heater) must NEVER be directly switched by relay. Use an external power contactor.

External Sensors wiring schematics

Fan Coil Thermostat — AGR25-01

External Sensors (S1, S2)

ANALOG SENSOR (Thermistor)

Remote temperature measurement

Applications:

- Supply air temperature
- Outdoor temperature
- Return air temperature
- Pipe changeover detection (2-pipe auto H/C switching)

Connection: S1 or S2 + G (0V ref)

DIGITAL SENSOR (Dry Contact)

ON/OFF state detection

Applications:

- Window open/close detector
- Key card / badge presence
- External PIR detector

Connection: S1 or S2 + G (0V ref)

 Sensors requiring external power must have their own power supply with adequate galvanic isolation.

Sensor wiring: Analog Sensors - Thermistor

AGRID AGR25-01

Sensor Type	Connection	Input	Signal	Applications
Thermistor	S1 or S2 + G (0V ref)	Analog	Resistance variation	Supply / Outdoor / Return air temp. / pipe changeover detection (2-pipe auto H/C switching) / etc ...

WIRING NOTES

Connect thermistor between **S1** (or S2) and **G**

- No external power supply needed
- 2-wire, no polarity
- Max cable length: 20 m

CONFIGURATION


Sensor type must be configured:

- Via thermostat parameter screen
- Via AGRID App (or via BMS)

SUPPORTED THERMISTORS

(reference list)

- NTC 5K
- NTC 10K Type II & Type III
- NTC 20K
- PT1000
- PT 500



i Thermistor provides remote temperature measurement — supply air, outdoor, return air temperature, pipe changeover detection (2-pipe auto H/C switching)

Sensor wiring: Dry Contact

AGRID AGR25-01

Sensor Type	Connection	Input	Signal	Applications
Dry Contact (Switch)	S1 or S2 + G (0V ref)	Digital	ON/OFF state	Window detector, key card, badge ...

WIRING NOTES

Connect switch between **S1** (or S2) and **G**

- No external power supply needed
- Voltage-free contact only
- Max cable length: 20 m


CONFIGURATION

Sensor type must be configured:

- Via thermostat parameter screen
- Via AGRID App (or via BMS)

APPLICATIONS

- Window open/close detector
- Key card / badge presence
- Any voltage-free contact



i Dry contact sensor provides ON/OFF state detection - no external power supply required

Sensor wiring: PIR Detector

AGRID AGR25-01

Sensor Type	Connection	Input	Signal	Power Supply
PIR Motion Detector	S1 or S2 + G (0V ref)	Digital	ON/OFF (dry contact)	External (separate PSU)

WIRING NOTES


Connect PIR dry contact output between **S1** (or S2) and **G**

- **PIR requires its own PSU**
Refer to PIR sensor manual for power supply specifications

CONFIGURATION

Sensor type must be configured:

- Via thermostat parameter screen
- Via AGRID App (or via BMS)



⚠ The PIR sensor requires an external power supply. Refer to the PIR sensor's instructions to ensure proper galvanic isolation and safety when connecting it to the thermostat. The external PSU must be isolated from the thermostat's extra-low voltage zone.

AGRID

Fan Coil Thermostat — AGR25-01

Full manual: a-grid.com/docs/thermostat/agr25-01

Support: support@a-grid.com

Manufacturer: Beijing Breeze Technology Co., Ltd.

Importer: AGRID SAS — 33 rue du Faubourg Saint-Antoine, 75011 Paris, France

