

RURAL WATER SUPPLY DEPARTMENT

Office of the Executive Engineer, Division No. 2

NOTICE INVITING e-TENDER No. EE/ELE/48/2026-27

Name of work: Rural piped water supply scheme — pumping and treated water supply.

Estimated cost put to tender: Rs. 406,45,000/-

Earnest Money Deposit: Rs. 5,17,000/-

Period of completion: 18 months

Last date of submission: 23.12.2026 up to 15:00 hrs

INSTRUCTIONS TO BIDDERS

1. The bidder must be registered with the Department in the appropriate class.
2. The Department reserves the right to accept or reject any bid without assigning any reason.
3. The tender documents may be downloaded from the e-procurement portal of the Government.
4. The bid shall remain valid for 90 days from the date of opening of the technical bid.
5. The bidder shall upload scanned copies of GST registration, PAN and audited balance sheets.

SCOPE OF WORK

This specification covers rural piped water supply scheme — pumping and treated water supply complete in all respects.

SECTION 3: HORIZONTAL CENTRIFUGAL PUMPS

3.1 Pumps shall conform to IS 1520:1980.

3.2 Each pump shall deliver 250 m³/h against a total head of 45 metres.

3.3 The pump efficiency at the duty point shall not be less than 78%. Casing shall be of cast iron and impeller shall be of bronze.

Signature of Bidder

3.4 Noise level at 1 metres from the pumpset shall not exceed 85 dBA.

PUMP DATA SHEET

Discharge: 250 m³/h

Total head: 45 metres

Make and type: (to be furnished by the bidder)

SECTION 4: DRIVE MOTORS

4.1 Motors shall be squirrel cage induction motors conforming to IS 325:1996.

4.2 The rated output of the motor shall be 37kW.

4.3 Motors shall be suitable for 415V $\pm$ 10%, 50 Hz $\pm$ 5%, 3 phase supply.

4.4 Motors shall be of efficiency class IE3 as per IS 12615:2018.

4.5 Degree of protection of the motor enclosure shall be IP55.

4.6 Motors shall have class F insulation with temperature rise limited to class B and shall be suitable for S1 duty.

4.7 Synchronous speed of the motor shall be 1500 RPM.

PART E — TREATED WATER QUALITY

5.1 Treated water supplied shall conform to IS 10500:2012.

5.2 PH OF TREATED WATER SHALL BE BETWEEN 6.5 AND 8.5.

5.3 TOTAL DISSOLVED SOLIDS SHALL NOT EXCEED 500 MG/L. Turbidity shall not be more than 1 NTU.

5.4 Fluoride shall not exceed 1.0 mg/L.

5.5 Nitrate shall not exceed 45 mg/L.

5.6 Arsenic shall not exceed 0.01 mg/L.

5.7 Total hardness as CaCO₃ shall not exceed 200 mg/L.

5.8 E. coli shall not be detectable in any 100 ml sample.

Signature of Bidder

6 TESTS AND INSPECTION

- 6.1 Pumps shall be tested at the works in accordance with IS 9137.
- 6.2 Pumps shall bear the ISI mark.
- 6.3 Routine tests on motors shall be carried out as per IS 4029.
- 6.4 Motors shall bear the ISI mark. Water samples shall be tested in a NABL accredited laboratory as per IS 3025 and IS 1622.
- 6.5 The equipment shall be inspected by the Engineer-in-charge at the manufacturer's works before dispatch.

7 DOCUMENTATION, WARRANTY AND TRAINING

- 7.1 Test reports shall be submitted to the Engineer-in-charge for each source.
- 7.2 The contractor shall submit detailed shop drawings for approval within 21 days of award of work.
- 7.3 THREE SETS OF OPERATION AND MAINTENANCE MANUALS SHALL BE HANDED OVER ON COMPLETION.
- 7.4 THE COMPLETE INSTALLATION SHALL BE GUARANTEED AGAINST DEFECTIVE DESIGN, MATERIAL AND WORKMANSHIP FOR A PERIOD OF 12 MONTHS FROM THE DATE OF HANDING OVER.
- 7.5 The contractor shall train the Department's operating staff in operation and routine maintenance.

SCHEDULE OF QUANTITIES

Sl. No. | Description | Unit | Qty

- 1 | Horizontal centrifugal pumpset 250 m³/hr at 45 m | Set | 3
- 2 | Squirrel cage induction motor 37 kW, 1500 rpm | No. | 3
- 3 | Water quality testing (complete set of parameters) | Sample | 48

LIST OF APPROVED MAKES

Pumps: Kirloskar Brothers / KSB / Mather & Platt

Motors: ABB / Siemens / Crompton Greaves / Kirloskar

Signature of Bidder

Page 3 of 4

Testing laboratory: NABL accredited

Note: In case of any discrepancy between drawings and specifications, the decision of the Engineer-in-charge shall be final.

Note: Drawings are indicative only and shall be verified at site.

Signature of Bidder with seal
Executive Engineer

Signature of Bidder
Page 4 of 4