

4 TECHNICAL SPECIFICATION — CONCRETE AND REINFORCEMENT

- (a) Plain and reinforced cement concrete works shall comply with IS 456:2000.
- (b) Grade of concrete for all RCC members shall be M30.
- (c) The nominal cover to reinforcement shall be 45 millimetre. Maximum free water-cement ratio shall be 0.55.
- (d) Cement content shall be not less than 320 kg/cu.m.
- (e) OPC 43 grade cement complying with IS 8112 shall be used.
- (f) Fe 500D TMT reinforcement bars complying with IS 1786:2008 shall be used.
- (g) Mix proportioning of concrete shall be done as per IS 10262:2019.
- (h) Concrete shall be cured for not less than 10 days.
- (i) Mechanical needle vibrators shall be used for compaction of concrete.

5 TESTS AND INSPECTION

- (a) Testing of concrete for compressive strength shall be done as per IS 516:1959.
- (b) The contractor shall furnish manufacturer's test certificates for every lot of cement and reinforcement.
- (c) Before despatch, the Engineer-in-charge will inspect the equipment at the maker's works.

6 DOCUMENTATION, WARRANTY AND TRAINING

- (a) Detailed shop drawings are to be submitted by the contractor for approval not later than 21 calendar days after the award of work.
- (b) On completion the contractor shall hand over three copies of the O&M manuals.
- (c) The contractor shall guarantee the whole installation for 12 months after handing over against faulty design, materials and workmanship.
- (d) Operation and routine maintenance training shall be given by the contractor to the Department's operators.

Signature of Bidder

BILL OF QUANTITIES

Sl. No. | Description | Unit | Qty

1 | RCC M30 in superstructure | cum | 420

2 | TMT reinforcement Fe 500D | MT | 58

LIST OF APPROVED MAKES

Cement: UltraTech / ACC / Ambuja; Steel: SAIL / TATA / JSW

Note: In case of any discrepancy between drawings and specifications, the decision of the Engineer-in-charge shall be final.

Note: Drawings are indicative only and shall be verified at site.

Signature of Bidder with seal

Executive Engineer

Signature of Bidder

Page 3 of 3