

RURAL WATER SUPPLY DEPARTMENT

Office of the Executive Engineer, Project Division

NOTICE INVITING e-TENDER No. CE/ELE/60/2026-27

Name of work: Rural piped water supply scheme — pumping and treated water supply.

Estimated cost put to tender: Rs. 194,22,000/-

Earnest Money Deposit: Rs. 2,57,000/-

Period of completion: 12 months

Last date of submission: 25.12.2026 up to 15:00 hrs

PART A — INSTRUCTIONS TO BIDDERS

1. The Department reserves the right to accept or reject any bid without assigning any reason.
2. Conditional bids will be summarily rejected.
3. The bidder shall submit the EMD in the form of online payment or bank guarantee from a scheduled bank.
4. The successful bidder shall furnish a performance guarantee of 5 % of the contract value within 15 days.
5. Bidders shall have completed at least one similar work of value not less than 40 % of the estimated cost during the last seven years.

GENERAL CONDITIONS OF CONTRACT

1. Income tax and GST shall be deducted at source as applicable.
2. Rates quoted shall be inclusive of all taxes, freight, insurance and transit risks.
3. All disputes shall be subject to arbitration under the Arbitration and Conciliation Act, 1996.
4. Payment shall be made within 30 days of receipt of bills duly certified by the Engineer-in-charge.
5. Liquidated damages at 0.5 % per week of delay shall be levied, subject to a maximum

Signature of Bidder

of 10 % of the contract value.

SCOPE OF WORK

This specification covers rural piped water supply scheme — pumping and treated water supply complete in all respects.

SECTION 3: HORIZONTAL CENTRIFUGAL PUMPS

1. The pumps shall comply with IS 1520:1980.
2. Discharge of each pump shall be 250 m³/hour.
3. Pump efficiency at the duty point shall be 78% (percent) minimum. The pump casing shall be cast iron and the impeller bronze.
4. The pumpset noise level measured 1 mtr away shall be limited to 85 decibels (A).

PUMP DATA SHEET

Rated discharge: 250 m³/hour

Rated total head: 45 mtr

Make and type: (to be furnished by the bidder)

SECTION 4: DRIVE MOTORS

1. Squirrel cage induction motors complying with IS 325:1996 shall be supplied.
2. Motor rated output shall be 37 k.W.. Motors are to operate on 415-volt $\pm$ 10% (percent), 50 Hertz $\pm$ 5% (percent), three phase supply.
3. Motors shall meet efficiency class IE3 of IS 12615:2018.
4. Insulation shall be class F, with temperature rise restricted to class B, for continuous S1 duty.
5. The motor synchronous speed shall be 1500 rpm..

PART E — TREATED WATER QUALITY

Signature of Bidder

Page 2 of 5

1. The quality of treated water shall comply with IS 10500:2012.
2. The pH value of treated water shall lie within 6.5 to 8.5.
3. TDS of treated water shall be limited to 500 mg per litre.
4. The turbidity of treated water shall be limited to 5 NTU..
5. Fluoride (as F) shall be limited to 1.0 mg per litre.
6. Nitrate (as NO₃) shall be limited to 45 mg per litre.
7. Arsenic (as As) shall be limited to 0.01 mg per litre.
8. Total hardness (as CaCO₃) shall be limited to 200 mg per litre.
9. No E. coli shall be detected in any 100 ml sample.

SECTION 6: TESTING, INSPECTION AND CERTIFICATION

1. Works testing of the pumps shall be done as per IS 9137.
2. Each motor shall be subjected to routine tests as per IS 4029.
3. All motors shall carry the ISI mark.
4. Testing of water samples shall be done at a NABL accredited laboratory as per IS 3025 and IS 1622.
5. Before despatch, the Engineer-in-charge will inspect the equipment at the maker's works.

7 DOCUMENTATION, WARRANTY AND TRAINING

1. The contractor shall submit test reports for every source to the Engineer-in-charge.
2. Detailed shop drawings are to be submitted by the contractor for approval not later than 21 calendar days after the award of work.
3. On completion the contractor shall hand over three copies of the O&M manuals.
4. The contractor shall guarantee the whole installation for 12 months after handing over against faulty design, materials and workmanship.
5. Operation and routine maintenance training shall be given by the contractor to the Department's operators.

Signature of Bidder

BILL OF QUANTITIES

Sl. No. | Description | Unit | Qty

1 | Horizontal centrifugal pumpset 250 m³/hr at 45 m | Set | 3

2 | Squirrel cage induction motor 37 kW, 1500 rpm | No. | 3

3 | Water quality testing (complete set of parameters) | Sample | 48

APPROVED MAKES OF MATERIALS

Pumps: Kirloskar Brothers / KSB / Mather & Platt

Motors: ABB / Siemens / Crompton Greaves / Kirloskar

Testing laboratory: NABL accredited

Note: In case of any discrepancy between drawings and specifications, the decision of the Engineer-in-charge shall be final.

Note: Drawings are indicative only and shall be verified at site.

Signature of Bidder with seal

Executive Engineer

Signature of Bidder

Page 4 of 5

