

PUBLIC HEALTH ENGINEERING DEPARTMENT

?????? ????????????

Office of the Executive Engineer, Division No. 2

NOTICE INVITING e-TENDER No. CE/ELE/33/2026-27

Name of work: Supply and installation of borewell submersible pumpsets and water quality testing.

Estimated cost put to tender: Rs. 107,78,000/-

Earnest Money Deposit: Rs. 5,45,000/-

Period of completion: 18 months

Last date of submission: 20.11.2026 up to 15:00 hrs

PART A — INSTRUCTIONS TO BIDDERS

1. The bidder shall submit the EMD in the form of online payment or bank guarantee from a scheduled bank.
2. Bids received after the due date and time shall not be considered.
3. The bidder shall upload scanned copies of GST registration, PAN and audited balance sheets.
4. The bidder must be registered with the Department in the appropriate class.
5. The successful bidder shall furnish a performance guarantee of 5 % of the contract value within 15 days.

SPECIAL CONDITIONS OF CONTRACT

1. Rates quoted shall be inclusive of all taxes, freight, insurance and transit risks.
2. The contractor shall indemnify the Department against all claims arising out of the work.
3. Payment shall be made within 30 days of receipt of bills duly certified by the Engineer-in-charge.
4. Income tax and GST shall be deducted at source as applicable.
5. Liquidated damages at 0.5 % per week of delay shall be levied, subject to a maximum of 10 % of the contract value.

Signature of Bidder

SCOPE OF WORK

This specification covers supply and installation of borewell submersible pumpsets and water quality testing complete in all respects.

3 TECHNICAL SPECIFICATION — BOREWELL SUBMERSIBLE PUMPSETS

- (a) SUBMERSIBLE PUMPSETS FOR BOREWELLS SHALL COMPLY WITH IS 8034:2018.
- (b) Duty point of each pumpset shall be 18 cu.m/hr at 90 metre total head.
- (c) The motors shall be wet type, water filled, complying with IS 9283:2013.
- (d) Flat submersible cables shall be copper conductor, PVC insulated, 3 core 6 Sq mm, complying with IS 694:2010 and tested to IS 10810.
- (e) An automatic starter with dry run protection and single phasing preventer shall be supplied with every pumpset.

SECTION 4: TREATED WATER QUALITY

- (a) The quality of treated water shall comply with IS 10500:2012.
- (b) The pH value of treated water shall lie within 6.5 to 8.5.
- (c) TDS of treated water shall be limited to 2000 mg per litre.
- (d) The turbidity of treated water shall be limited to 1 NTU..
- (e) Fluoride (as F) shall be limited to 1.5 mg per litre.
- (f) Nitrate (as NO₃) shall be limited to 45 mg per litre.
- (g) Arsenic (as As) shall be limited to 0.01 mg per litre.
- (h) Total hardness (as CaCO₃) shall be limited to 200 mg per litre. No E. coli shall be detected in any 100 ml sample.

SECTION 5: TESTING, INSPECTION AND CERTIFICATION

- (a) All pumpsets shall carry the BIS Standard Mark.
- (b) Testing of water samples shall be done at a NABL accredited laboratory as per IS 3025.

Signature of Bidder

(c) Before despatch, the Engineer-in-charge will inspect the equipment at the maker's works.

6 DOCUMENTATION, WARRANTY AND TRAINING

(a) The contractor shall submit test reports for every source to the Engineer-in-charge.

Detailed shop drawings are to be submitted by the contractor for approval not later than 21 calendar days after the award of work.

(b) On completion the contractor shall hand over three copies of the O&M manuals.

(c) The contractor shall guarantee the whole installation for 12 months after handing over against faulty design, materials and workmanship.

(d) OPERATION AND ROUTINE MAINTENANCE TRAINING SHALL BE GIVEN BY THE CONTRACTOR TO THE DEPARTMENT'S OPERATORS.

SCHEDULE OF QUANTITIES

Sl. No. | Description | Unit | Qty

1 | Submersible pumpset 18 m³/hr at 90 m head | Set | 12

2 | Water quality testing (complete set of parameters) | Sample | 48

APPROVED MAKES OF MATERIALS

Submersible pumps: CRI / Kirloskar / Texmo

Testing laboratory: NABL accredited

Note: In case of any discrepancy between drawings and specifications, the decision of the Engineer-in-charge shall be final.

Note: Quantities are approximate and may vary during execution.

Signature of Bidder with seal

Executive Engineer

Signature of Bidder

Page 3 of 3