



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	90/05/21	Date:	10/05/2021	Prnt.Time :	09:54
Substation:	FIFTH RING ROAD-A	Make:	COG	P.M:	03/03/2013
		Maint:	ARV	Comm:	05/21/1976

Equip./Unit Affected : 75MVA Tr.# 4

Nature of Fault : Prot. clearance is required for the mentioned transformer.

Concerned Group & Engr: Salem R Alenezi

Technicians:- 1-

Section Head :

2-

Action Taken :

Tr#4 75 MVA panel # 17
Protection side clear

Relays ok and Clear
O/C & E/F Clear

Dcc informed S/S Clear

Concerned Group & Engr :

Date: 10/5/2021

Director :

Section Head :