



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	66/05/21	Date:	06/05/2021	Prnt. Time :	12:06
Substation:	JALEEB-A	Make:	SIE	P.M:	21/12/2020
		Maint:	SIE	Comm:	07/26/1982

Equip./Unit Affected : Omariya "A" 132kV F

Nature of Fault : Prot. clearance, Solkor Stabiltiy and I/Trip required for the mentioned feeder. PME has to follow.

Concerned Group & Engr: **Technicians:-** 1-
Section Head : 2-

Action Taken :

Protection clear
Polarity checked
Intertrip tested
Stability done
JCC informed all clear

Abdullah Almazdi

Concerned Group & Engr :

Date: 9/5/2021

Director :

Section Head :