



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	4/05/21	Date:	02/05/2021	Prnt.Time :	09:00
Substation:	ABU HALIFA-C	Make:	SIE	P.M:	25/05/2017
		Maint:	SIE	Comm:	08/12/1986

Equip./Unit Affected : KOCE "A" 132kV F

Nature of Fault : Prot. clearance is required for the mentioned feeder. The same would be closed on 06.00AM On 06/05/2021.

Concerned Group & Engr: Husain Dehrab **Technicians:-** 1-
Section Head : 2-

Action Taken :

Protection is clear. Polarity test is applied. Intertrip is clear and the feeder is normalized. NCC informed.

Concerned Group & Engr :

Date: 6 5 /2021

Director :

Section Head :