



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	3/05/21	Date:	02/05/2021	Prnt.Time :	08:59
Substation:	KUWAIT OIL COMPANY-A	Make:	SIE	P.M:	29/06/2016
		Maint:	SIE	Comm:	02/24/2004

Equip./Unit Affected : Abu Halifa "C" 132KV F

Nature of Fault : Prot. clearance is required for the mentioned feeder. The same would be closed on 06.00AM On 06/05/2021.

Concerned Group & Engr: Ali Boualiyan

Technicians:- 1-

Section Head :

2-

Action Taken :

Protection is clear for both back up and main protection.polarity and intertrip for the feeder are clear.the feeder has been normalized with minimum settings from both sides without any issues and the settings have been normalized afterwards.Dcc has been informed and s/s is clear.

6/5/2021

Concerned Group & Engr :

Date: / /

Director :

Section Head :