



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	363/11/22	Date:	28/11/2022	Prnt.Time :	08:55
Substation:	OMERIYA-A EXT	Make:	COG	P.M:	19/04/2018
		Maint:	ALSTOM	Comm:	06/12/1984

Equip./Unit Affected :

Nature of Fault : 132kV G/Alarm is appeared at 08.45 Hr. and Still existing. PME has to follow.

Concerned Group & Engr: Salem R Alenezi

Technicians:- 1-

Section Head : 2-

Action Taken :

Alarm came from firefighter
Protection side clear

DCC informed

28/11/2022

Concerned Group & Engr :

Date: / /

Director :

Section Head :