



## TROUBLE SHOOTING REPORT

PSMD (SABHAN)

<b>Ref. No:</b>	360/11/22	<b>Date:</b>	28/11/2022	<b>Prnt.Time :</b>	08:34
<b>Substation:</b>	SALMIYA-A	<b>Make:</b>	ABB	<b>P.M:</b>	03/03/2019
		<b>Maint:</b>		<b>Comm:</b>	04/22/1979

**Equip./Unit Affected :** JABR "A1" 132 KV BAY #2

**Nature of Fault :** COPA & COPT checking.CME M.Jamal reported that there is no DC in the cable gauge.PME has to follow.

**Concerned Group & Engr:** ..... **Technicians:-** 1-  
Section Head : ..... 2-

**Action Taken :**

-ve not available in gage side checked found COPA  
flag faulty replaced it with spare from 33kv bay#14  
JCC informed all clear

**Concerned Group & Engr :** Abdullah Almazdi

**Date:** 28/11/2022

**Director :** .....

**Section Head :** .....