



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	270/11/22	Date:	20/11/2022	Prnt.Time :	08:59
Substation:	SOUTH SABAH AL SALEM-E	Make:	MIT	P.M:	10/03/2022
		Maint:		Comm:	09/25/1995

Equip./Unit Affected : DC

Nature of Fault : DC supply fail alarm is appeared on 18/11/20222 . Batt/F checked and reported that is from load side . PME has to follow .

Concerned Group & Engr: Yousef Rashed
Section Head : _____
Technicians:- 1- Saad AlMutairi
2- _____

Action Taken :

Found ' Tripping 220V battery charger faulty' alarm.
Reset the alarm. S/s clear.
DCC informed.

Concerned Group & Engr : _____

Date: 20 / 11 / 2022

Director : _____

Section Head : _____