



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	276/11/22	Date:	20/11/2022	Prnt.Time :	09:44
Substation:	AMIRI DIWAN-M	Make:	TRE	P.M:	22/06/2017
		Maint:		Comm:	09/19/1995

Equip./Unit Affected : DC

Nature of Fault : DC supply fail alarm is appeared on 19/11/2022 and still existing (need entrance permission) . PME has to follow .

Concerned Group & Engr: Othman alloughani **Technicians:-** 1- Shafi alrashidi
Section Head : 2-

Action Taken :

Alarm reset from charger side. Protection clear dcc informed

Concerned Group & Engr :

Date: 20/11/2022

Director :

Section Head :