



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	383/11/22	Date:	30/11/2022	Prnt.Time :	08:55
Substation:	KEIFAN-M	Make:	TRE	P.M:	24/12/2020
		Maint:		Comm:	03/05/1973

Equip./Unit Affected : SHKH"A" 33 KV F # 1

Nature of Fault : Protection clearance is required for A/M F . Requested by CME Ahmed Alaa (69005536) . PME has to follow .

Concerned Group & Engr: Amer Alansari **Technicians:-** 1-

Section Head : 2-

Action Taken :

Protection relays solker, OC and EF for bay4 33kv have been tested and clear.

Concerned Group & Engr :

Date: / /

Director :

Section Head :