



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	265/11/22	Date:	20/11/2022	Prnt.Time :	08:12
Substation:	SHUAIBA SWITCHING-A	Make:	HIT	P.M:	03/03/2019
		Maint:		Comm:	02/25/1980

Equip./Unit Affected : SALT AND CHLORINE"A" 132 KV F

Nature of Fault : PC fault alarm is appeared at 2:53 Hr for A/M F . PME Abdulla Aljwesri checked and reported that threr is Intertrip problem . PME has to follow .

Concerned Group & Engr: Salem R Alenezi **Technicians:-** 1-
Section Head : 2-

Action Taken :

I/T Alspa Card # 613 was sticky
S/S now clear

DCC informed

20/11/2022

Concerned Group & Engr :

Date: / /

Director :

Section Head :