



## TROUBLE SHOOTING REPORT

PSMD (SABHAN)

<b>Ref. No:</b>	281/11/22	<b>Date:</b>	20/11/2022	<b>Prnt.Time :</b>	10:24
<b>Substation:</b>	WEST JALEEB-A	<b>Make:</b>	SIE	<b>P.M:</b>	10/02/2022
		<b>Maint:</b>		<b>Comm:</b>	12/23/2002

**Equip./Unit Affected :** WEST JALEEB"D" 132 KV F

**Nature of Fault :** 132 KV G/A is appeared on 18/11/2022 . PME Mishari Ali Cleared temporary by isolating device for O/C and earth fault relay for A/M F due to faulty and need to replace . PME has to follow .

Concerned Group & Engr: **Fahad Shateel**      **Technicians:-** 1- **Bateel**  
Section Head :      2-

**Action Taken :**

OC/EF relay was faulty and has been replaced by new one.

Protection is clear

Dcc informed

Concerned Group & Engr :

Date: **20-11-2022** / /

Director :

Section Head :