



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	330/10/22	Date:	30/10/2022	Prnt.Time :	10:05
Substation:	JAHRA-B	Make:	SIE	P.M:	28/11/2018
		Maint:		Comm:	07/05/1979

Equip./Unit Affected : QASR"M" 33 KV F # 3

Nature of Fault : Protection clearance and make the necessary adjustments to the protective devices to match the fiber-optic cables are required for A/M F . Please check the attached letter from CMD .

Concerned Group & Engr: Othman Alloughani **Technicians:-** 1- Shafi alrashidi
Section Head : 2-

Action Taken : Protection clear dcc informed

Concerned Group & Engr :

Date: 24/11/2022

Director :

Section Head :