



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	341/11/22	Date:	24/11/2022	Prnt.Time :	10:12
Substation:	PLAJAT-M	Make:	AHL	P.M:	21/02/2021
		Maint:		Comm:	05/16/1973

Equip./Unit Affected : 11 KV F Panel # 01

Nature of Fault : A/M F CB is showing undefined indication during close it by Distribution Construction Eng Nada (66681894) . SME Omer Alkhayat reported it is from protection side . PME has to follow .

Concerned Group & Engr: [Salem R Alenezi](#) Technicians:- 1-
Section Head : 2-


Action Taken :

Contact D1 for CB open position in control panel was faulty

Changed the contact with spear panel 02

Alarm now clear

CB open and closed 👍
DCC informed

Concerned Group & Engr :		Date: 24/11/2022
Director :	Section Head :	