



## TROUBLE SHOOTING REPORT

PSMD (SABHAN)

<b>Ref. No:</b>	357/11/22	<b>Date:</b>	28/11/2022	<b>Prnt.Time :</b>	07:59
<b>Substation:</b>	SHUAIBA-AX	<b>Make:</b>	HIT	<b>P.M:</b>	
		<b>Maint:</b>		<b>Comm:</b>	29/01/2003

**Equip./Unit Affected :** FAHL "E" 132 KV Feeder

**Nature of Fault :** An arrangment to check the DC Circuit of COPA/COPT is required.Requested by U.G Cable&OHL Maint Dept.Please check the attached letter.PME has to follow.

**Concerned Group & Engr:** Mohammad almutairi  
**Section Head :** .....

**Technicians:-** 1-  
2-

**Action Taken :**

Regarding to the subject above, pin 44 at terminal X2 was open.  
Link was normalised, protection clear and dcc was informed.

**Concerned Group & Engr :** Mohammad almutairi

**Date:** 29 / 11 / 2022

**Director :** .....

**Section Head :** .....