



## TROUBLE SHOOTING REPORT

PSMD (SABHAN)

<b>Ref. No:</b>	348/11/22	<b>Date:</b>	27/11/2022	<b>Prnt.Time :</b>	08:21
<b>Substation:</b>	MANGAF-C	<b>Make:</b>	SIE	<b>P.M:</b>	19/07/2016
		<b>Maint:</b>		<b>Comm:</b>	06/18/1990

**Equip./Unit Affected :** 11 KV F Panel # 20

**Nature of Fault :** Dist. Eng failed to colse A/M F . SME Abdulla Alajmi (55406868) checked and reported that is from protection side . (Note the feeder is closed from the ring main S/stn side . PME has to follow .

Concerned Group & Engr: ..... **Technicians:-** 1-  
Section Head : ..... 2-

**Action Taken :**

There was CB trip alarm and dist. Eng didn't close  
breaker because of that alarm  
Reset alarm all clear  
SHCC informed

Concerned Group & Engr : Abdullah Almazdi

Date: 27/11/2022

Director : .....

Section Head : .....