



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	209/11/22	Date:	14/11/2022	Prnt.Time :	11:36
Substation:	PLAJAT-M	Make:	AHL	P.M:	21/02/2021
		Maint:		Comm:	05/16/1973

Equip./Unit Affected : DC

Nature of Fault : DC supply fail alarm is appeared at 10:03 Hr . Bat/F Waleed Alrashedi checked and reported that is from load side . PME has to follow .

Concerned Group & Engr: Technicians:- 1-
Section Head : 2-

Action Taken :

Visited the substation there was Dc earth fault. while measuring the fault the MCB of panel 18 in 11KV tripped so, I normalize it and then normalize another mcb in the disturbance board and the alarm has been cleared.

Concerned Group & Engr : Date: / /

Director : Section Head :