



## TROUBLE SHOOTING REPORT

PSMD (SABHAN)

<b>Ref. No:</b>	13/10/23	<b>Date:</b>	01/10/2023	<b>Prnt.Time :</b>	09:52
<b>Substation:</b>	AHMADI-A	<b>Make:</b>	TOS	<b>P.M:</b>	01/04/2021
		<b>Maint:</b>		<b>Comm:</b>	17/01/1989

**Equip./Unit Affected :** 50 MVAR S/R # 1 , # 2

**Nature of Fault :** Protection clearances are required for the A/M shunt reactors . Requested by Shub DCC .

**Concerned Group & Engr:** Salem R Alenezi **Technicians:-** 1- Ayoub Ali Hussain Alqattan  
Section Head : 2-

**Action Taken :**

Shunt reactors clear 50MVA  
All relays clear and healthy  
Protection side clear  
S/S clear

DCC informed

1/10/2023

**Concerned Group & Engr :**

**Date:** / /

**Director :**

**Section Head :**