



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	6/10/23	Date:	01/10/2023	Prnt. Time :	08:04
Substation:	SABAH AL AHMAD-3Z	Make:	HYUNDA	P.M:	
		Maint:		Comm:	09/08/2015

Equip./Unit Affected : 250 MVAR S/R # 1 , 45 MVAR S/R # 1 , # 2 , # 3 , # 4

Nature of Fault : Protection clearances are required for the A/M shunt reactors . Requested by NCC

Concerned Group & Engr: Fahad Shateel **Technicians:-** 1- Salem Alazmi
Section Head : 2-

Action Taken :

All the mentioned Shunt-Reactors are
clear from protection side

Ncc informed

Concerned Group & Engr :

Date: / /
1-10-2023

Director :

Section Head :