



TROUBLE SHOOTING REPORT

PSMD (SABHAN)

Ref. No:	47/10/23	Date:	01/10/2023	Prnt. Time :	12:52
Substation:	SHUWAIKH IND-M	Make:	SIE	P.M.:	20/01/2022
		Maint:		Comm:	03/19/2007
Equip./Unit Affected :	UNIV"M" 33 KV F				

Nature of Fault : Polarity check , stability test and normalize SOLKOR are required for the A/M F .
Requested by CME Mohamed Akber (99471194) . PME has to follow .

Concerned Group & Engr: Husain Dahrab Technicians:- 1-
Section Head : 2-
.....

Action Taken :

Pilot polarity tested. DCC has been informed.

Concerned Group & Engr : Date: 2./ 10. 2023

Director :

Section Head :