

ADDENDUM NO. 3

Issued 3 November 2026
Tender NUPA/ISTP/2026/014

Wadi Sirhan Independent Sewage Treatment Plant

This Addendum amends the time for receipt of Proposals and the submission address, introduces registration of the persons delivering Proposals, extends the Proposal validity period, removes the model audit opinion from the Proposal, re-letters Volume I Clause 9.1, amends Volume II Clauses 3.5, 4.4 and 8.4, reissues Volume II Table 2-2, and responds to clarification requests 15 to 21. The Proposal Due Date is unchanged.

This Addendum forms part of the RFP Documents and takes precedence in accordance with Volume I Clause 3.2. Bidders shall acknowledge receipt in Form 4-A. All other terms of the RFP Documents remain unchanged.

1. RECITALS

- 1.1 This Addendum is issued under Volume I Clause 5.3 and takes precedence over Addenda Nos. 1 and 2 in accordance with Volume I Clause 3.2.
- 1.2 Clarification request 18 was withdrawn by the Bidder that submitted it and is not answered.

2. TIME AND PLACE FOR RECEIPT OF PROPOSALS

- 2.1 In Volume I Clause 6.1, as amended by Addendum No. 1 Section 2.1, '14:00 hours Riyadh time' is deleted and '**11:00 hours Riyadh time**' is substituted. The date of Thursday 26 November 2026 is not changed.
- 2.2 The second sentence of Section 2.1 of Addendum No. 1 ('The time of 14:00 Riyadh time is unchanged.') ceases to have effect.
- 2.3 Volume I Appendix 3 is deleted and replaced by the following: 'Tender Box 2, First Floor, Northern Utilities Procurement Authority, **Administrative Building A**, Sakaka. Marked: "NUPA/ISTP/2026/014 — NOT TO BE OPENED BEFORE 11:00 ON THE PROPOSAL DUE DATE".'
- 2.4 The following new Clause 6.8 is **inserted** in Volume I after Clause 6.7:

'6.8 Each Bidder shall, not later than **five (5) Working Days before the Proposal Due Date**, register through the Portal the names and identity document numbers of not more than two (2) representatives who will deliver its Proposal. Access to Administrative Building A will be refused to any person who is not so registered. A Proposal that is not received by the time stated in Clause 6.1 for that reason shall be treated as a late Proposal under Clause 6.6.'

3. PROPOSAL VALIDITY

- 3.1 In Volume I Clause 7.1, 'one hundred and fifty (150) days' is deleted and '**one hundred and eighty (180) days**' is substituted.
- 3.2 In Volume I Clause 6.3, 'one hundred and eighty (180) days' is deleted and '**two hundred and ten (210) days**' is substituted.
- 3.3 Paragraph 2 of Form 4-A shall be read accordingly.

4. FINANCIAL MODEL AUDIT OPINION

- 4.1 In Volume I Clause 10.3, the words ', and shall be accompanied by an opinion from an independent model auditor addressed to the Authority' are **deleted**. No model audit opinion is required with the Proposal.
- 4.2 The following new Clause 12.5 is **inserted** in Volume I after Clause 12.4:

‘12.5 The Preferred Bidder shall deliver to the Authority, not later than **forty-five (45) days after the Preferred Bidder Notification**, an opinion from an independent model auditor on the Financial Model, addressed to the Authority.’

4.3 In Form 4-F, the rows ‘Model auditor’ and ‘Date of model audit opinion’ are deleted.

5. AMENDMENTS TO VOLUME II CLAUSES 3.5, 4.4 AND 8.4

5.1 In Volume II Clause 3.5, ‘45 dB(A) by night’ is deleted and **‘40 dB(A) by night’** is substituted. The daytime limit is unchanged.

5.2 Section 4.1 of Addendum No. 2 is **revoked**. The period in Volume II Clause 4.4 is seventy-two (72) hours, as originally issued.

5.3 In Volume II Clause 8.4, ‘22% dry solids’ is deleted and **‘25% dry solids’** is substituted, and the second sentence is deleted and replaced by: **‘No sludge shall be disposed of to landfill without the Authority's prior written consent.’**

6. REISSUED VOLUME II TABLE 2-2

6.1 Table 2-2 of Volume II is deleted and replaced by Table 2-2 (revised) at Appendix A to this Addendum, including the Notes to that Table. The principal changes are an increase in the influent nitrogen concentrations, the addition of ammonia nitrogen and a reduction in the minimum design temperature.

6.2 Bidders shall reflect Table 2-2 (revised) in the process design submitted under Volume II Section 3.

7. RE-LETTERING OF VOLUME I CLAUSE 9.1

7.1 Following the insertion of Form 4-G by Section 7.1 of Addendum No. 2, the items of Volume I Clause 9.1 are re-lettered: Form 4-G is item **(f)**, and former items (f) to (i) become items **(g) to (j)** respectively. The numbered dividers in Envelope A shall follow the re-lettered list.

7.2 The Index of Forms in Volume IV is amended by adding, after the entry for Form 4-F, an entry for Form 4-G with the title ‘Cybersecurity Compliance Undertaking’, Envelope ‘A’ and Status ‘Mandatory’.

8. RESPONSES TO CLARIFICATION REQUESTS 15 TO 21

No	Bidder question	Authority response
15	Addendum No. 1 response 3 permits a Bid Bond issued by a licensed branch of a foreign bank. Must such a Bid Bond also be confirmed by a bank incorporated in the Kingdom?	The response to clarification request 3 in Addendum No. 1 is withdrawn. The Bid Bond shall be issued by a bank incorporated in the Kingdom that meets the rating requirement in Volume I Clause 6.4. A Bid Bond issued by a branch of a foreign bank, whether or not confirmed, will not be accepted.
16	Must the notarised Powers of Attorney required by Volume I Clause 9.1 be legalised where they are executed outside the Kingdom?	Yes. A Power of Attorney executed outside the Kingdom shall, in addition to notarisation, be legalised by an embassy or consulate of the Kingdom in the country of execution, or apostilled where that country is a party to the Apostille Convention. The Powers of Attorney are item (i) of Volume I Clause 9.1 as re-lettered by Section 7 of this Addendum. A Power of Attorney that does not comply will be treated as not submitted.
17	Following response 10 in Addendum No. 2, is any guarantee or other security required in respect of the proposed O&M Operator?	No. The response to clarification request 10 in Addendum No. 2 is confirmed. Volume I Clause 8.7 requires a Parent Company Guarantee in respect of the proposed EPC Contractor only.
18	Withdrawn.	Not answered. See Section 1.2 of this Addendum.
19	Further to response 7 in Addendum No. 2, will Volume V Clause 3.1 be conformed to Volume I Clause 12.1 so that the twenty-five (25) year term runs from PCOD?	The Authority intends to address the commencement of the term in the execution version of the Project Agreement. No amendment is made to Volume I or Volume V by this Addendum. A Bidder that wishes to propose wording may do so in Form 4-E.

No	Bidder question	Authority response
20	Volume I Clause 6.5 requires one electronic copy of the Proposal, but Volume I Clause 10.1 requires the Financial Model to be placed in Envelope B. How is the Financial Model to be submitted?	The Financial Model shall be submitted on a second, separate encrypted USB media placed in Envelope B. The electronic copy required by Volume I Clause 6.5 shall contain Envelope A only. The password for each USB media shall be submitted through the Portal within one (1) hour after the Proposal Due Date. Commercial information on the Envelope A media will be treated in accordance with Volume I Clause 6.2.
21	In view of the changes made by Addenda Nos. 1 and 2, will the Authority extend the Proposal Due Date?	No. The date for receipt of Proposals is not extended. Bidders' attention is drawn to Section 2 of this Addendum.

FICTIONAL — ASSESSMENT PACK

APPENDIX A — REVISED TABLE 2-2

Table 2-2 of Volume II is reissued below in accordance with Section 6 of this Addendum. Bidders shall use this version.

Table 2-2 (revised) — Design influent characteristics

Parameter	Unit	Average	Peak (design)
BOD ₅	mg/l	320	480
COD	mg/l	640	950
Total Suspended Solids	mg/l	350	520
Total Nitrogen	mg/l	60	85
Ammonia nitrogen (NH ₄ -N)	mg/l	42	62
Total Phosphorus	mg/l	9	16
Temperature	°C	24	34 (max) / 12 (min)

Notes to Table 2-2 (revised):

- (1) Concentrations are flow-weighted 24-hour composite values measured at the inlet works. Peak (design) values are 95th percentile values.
- (2) The minimum temperature of 12 °C shall be used for the design of the nitrification stage.
- (3) Bidders shall submit, as an appendix to the Technical Proposal, a process simulation report demonstrating that the effluent quality in Table 2-4, as amended, is achieved under the Peak (design) values in this Table at the minimum design temperature. The report shall not exceed twenty-five (25) pages and is excluded from the page limit in Volume I Clause 9.2. **A Technical Proposal that does not include the report will be awarded no marks under criterion A of Table 1-1 (revised).**
- (4) In Volume II Clause 2.3, '50% of nominal capacity' is deleted and '**25% of nominal capacity**' is substituted.