

## ADDENDUM NO. 3

Issued 5 November 2026  
Tender NUPA/ISTP/2026/014

### Wadi Sirhan Independent Sewage Treatment Plant

This Addendum amends the Proposal Due Date, the clarification period, the Bid Bond amount and the number of copies to be submitted, amends footnote 12 to Volume I Clause 8.5 and Volume I Clauses 8.6 and 12.2, inserts a new Volume I Clause 10.5, amends Volume II Tables 2-4 and 2-6 and Form 4-C, and responds to clarification requests 15 to 20.

This Addendum forms part of the RFP Documents and takes precedence in accordance with Volume I Clause 3.2. Bidders shall acknowledge receipt in Form 4-A. All other terms of the RFP Documents remain unchanged.

### 1. RECITALS

- 1.1 This Addendum is issued under Volume I Clause 5.3 and takes precedence over Addenda Nos. 1 and 2 in accordance with Volume I Clause 3.2.
- 1.2 A reference in this Addendum to a Clause, Table or Form is to that Clause, Table or Form as amended by Addenda Nos. 1 and 2, unless otherwise stated.

### 2. AMENDMENT TO THE PROPOSAL DUE DATE

- 2.1 Volume I Clause 6.1, as amended by Addendum No. 1 Section 2.1, is further amended by deleting 'Thursday 26 November 2026' and substituting '**Thursday 10 December 2026**'. The time of 14:00 Riyadh time is unchanged.
- 2.2 Section 2.2 of Addendum No. 1 applies mutatis mutandis to the amendment made by Section 2.1 of this Addendum.
- 2.3 In the revised Form 4-A at Appendix A to Addendum No. 1, the entry against 'Proposal Due Date', which was not updated by that Addendum, is corrected to read '**10 December 2026, 14:00 Riyadh time**'.

### 3. AMENDMENT TO VOLUME I CLAUSE 5.2

- 3.1 In Volume I Clause 5.2, 'ten (10) Working Days' is deleted and '**fifteen (15) Working Days**' is substituted. This amendment applies to Clause 5.2 only. The periods of ten (10) Working Days in Volume I Clause 12.3 and Volume V Clause 29.4 are unchanged.
- 3.2 In Volume I Clause 5.2, 'Requests received after that time will not be answered.' is deleted and '**Requests received after 14:00 Riyadh time on the last day for submission will not be answered.**' is substituted.

### 4. AMENDMENT TO VOLUME I CLAUSE 6.4

- 4.1 In Volume I Clause 6.4, 'SAR 4,500,000 (four million five hundred thousand Saudi Riyals)' is deleted and '**SAR 6,000,000 (six million Saudi Riyals)**' is substituted. The other requirements of Clause 6.4 are unchanged.

### 5. AMENDMENT TO VOLUME I CLAUSE 6.5

- 5.1 In Volume I Clause 6.5, the first sentence is deleted and replaced by: '**Each Proposal shall be submitted as one (1) marked original and one (1) searchable electronic copy on encrypted USB media.**' The requirement to submit three (3) hard copies is **deleted**. The second and third sentences of Clause 6.5 are unchanged.

### 6. AMENDMENT TO FOOTNOTE 12 TO VOLUME I CLAUSE 8.5

- 6.1 In footnote 12 to Volume I Clause 8.5, '80,000 m<sup>3</sup>/day' is deleted and '**60,000 m<sup>3</sup>/day**' is substituted. The remainder of footnote 12, including the number of reference plants, the look-back period and the consequence of rejection, is unchanged.

## 7. AMENDMENT TO VOLUME I CLAUSE 8.6

7.1 In Volume I Clause 8.6, as reinstated by Addendum No. 2 Section 9.1, ‘thirty-five per cent (35%)’ is deleted and ‘**thirty per cent (30%)**’ is substituted. The second sentence of Clause 8.6 as reinstated is unchanged.

## 8. NEW VOLUME I CLAUSE 10.5 AND RENUMBERING

8.1 The following new Clause 10.5 is **inserted** in Volume I after Clause 10.4:

‘**10.5** The Availability Payment quoted in Form 4-F shall not exceed **SAR 210,000,000 per annum** (year 1 of operations, exclusive of value added tax). A Proposal that quotes an Availability Payment exceeding this amount shall be rejected.’

8.2 Existing Volume I Clauses 10.5 and 10.6 are renumbered **10.6** and **10.7** respectively. A reference to Clause 10.5 or Clause 10.6 in Volumes I to V or in Addenda Nos. 1 and 2, including in the response to clarification request 14 in Addendum No. 2, shall be read as a reference to Clause 10.6 or Clause 10.7 respectively.

## 9. AMENDMENT TO VOLUME I CLAUSE 12.2

9.1 In Volume I Clause 12.2, ‘two hundred and seventy (270) days’ is deleted and ‘**three hundred (300) days**’ is substituted. The period for Commercial Close is unchanged.

9.2 The response to clarification request 13 in Addendum No. 2 is **superseded**.

## 10. AMENDMENT TO VOLUME II TABLE 2-4

10.1 In Volume II Table 2-4, in the row for **Total Suspended Solids (TSS)**, the limit is amended from the value shown to **15 mg/l** and the basis of assessment is amended to ‘**Maximum, any single sample**’. All other entries in Table 2-4, including the Total Nitrogen limit as amended by Addendum No. 2, are unchanged.

## 11. AMENDMENT TO VOLUME II TABLE 2-6

11.1 In Volume II Table 2-6, in row 2-6.2 (Peak hourly flow (design)), ‘7,500’ is deleted and ‘**9,000**’ is substituted. The unit is unchanged. No other row of Table 2-6 is amended.

11.2 Bidders shall reflect the amended flow in the hydraulic design submitted under Volume II Section 4.

## 12. AMENDMENT TO FORM 4-C

12.1 Form 4-C is amended by adding, after the fifth numbered declaration, the following sixth declaration: ‘Sixth: that neither the member nor any of its directors has, within the preceding five (5) years, been convicted in the Kingdom of an offence involving fraud, bribery or corruption.’

12.2 Each member of the Bidder shall give the sixth declaration in its Form 4-C. Volume I Clause 9.4 applies.

## 13. RESPONSES TO CLARIFICATION REQUESTS 15 TO 20

| No | Bidder question                                                                                                                                                          | Authority response                                                                                                                                                                                       |
|----|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 15 | Must the Local Content Certificate required by Volume I Clause 8.6, as reinstated by Addendum No. 2, be submitted with the Proposal or may it follow at Financial Close? | It shall be submitted with the Proposal, in Envelope A, as part of the evidence required under Section 8 (Volume I Clause 9.1). The required ratio is amended by Section 7 of this Addendum.             |
| 16 | Volume II Clause 6.1 requires unattended operation of the whole Facility and a permanently manned central control room. Must the control room be manned 24 hours a day?  | No. In Volume II Clause 6.1, ‘a permanently manned central control room’ is deleted and ‘a central control room manned between 06:00 and 22:00 daily’ is substituted. Volume II Clause 8.3 is unchanged. |
| 17 | May a consortium member rely on a reference project delivered by its parent company or another affiliate for the purposes of Volume I Clause 8.5?                        | No. Only a reference project for which the consortium member itself was responsible for design, construction or operation will be considered. A reference project of an affiliate will be disregarded.   |

| No | Bidder question                                                                                                         | Authority response                                                                                                                   |
|----|-------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------|
| 18 | Does the Total Nitrogen limit introduced by Addendum No. 2 apply during the reliability run under Volume II Clause 7.2? | Yes. Volume II Clause 7.2 requires every parameter in Table 2-4, as amended, to be met during the reliability run.                   |
| 19 | Will a further site visit be offered?                                                                                   | No further site visit will be held. Volume I Clause 5.5 applies.                                                                     |
| 20 | Are the appendices permitted by Volume II counted within the 150-page limit introduced by Addendum No. 2?               | No. Volume I Clause 9.2, as amended by Addendum No. 2, excludes the Form Sheets and the appendices expressly permitted by Volume II. |

FICTIONAL — ASSESSMENT PACK