

ADDENDUM NO. 3

Issued 15 November 2026
Tender NUPA/ISTP/2026/014

Wadi Sirhan Independent Sewage Treatment Plant

This Addendum consolidates Volume I Clauses 6.6 and 6.7 without change of substance, amends the definition of Availability Payment and the indexation of the Availability Payment under Volume V Clause 29.2, adds a membrane filtration requirement to Volume II Clause 3.1, replaces the odour criterion in Volume II Clause 3.5 by reference to the Environmental and Social Impact Assessment, inserts a new Volume II Clause 5.6 limiting the height of permanent structures at the site in accordance with Table 5-1, and responds to clarification requests 15 to 21.

This Addendum forms part of the RFP Documents and takes precedence in accordance with Volume I Clause 3.2. Bidders shall acknowledge receipt in Form 4-A. All other terms of the RFP Documents remain unchanged.

1. RECITALS

- 1.1 This Addendum is issued under Volume I Clause 5.3 and takes precedence over Addenda Nos. 1 and 2 in accordance with Volume I Clause 3.2.
- 1.2 A reference in this Addendum to a Clause, Table or Form is to that Clause, Table or Form as amended by Addenda Nos. 1 and 2, unless otherwise stated.
- 1.3 Requests for clarification received after the time stated in Volume I Clause 5.2 have not been answered.

2. CONSOLIDATION OF VOLUME I CLAUSES 6.6 AND 6.7

- 2.1 Volume I Clauses 6.6 and 6.7 are deleted and replaced by the following single Clause 6.6:

‘6.6 A Bidder may withdraw its Proposal at any time before the Proposal Due Date, and may modify its Proposal not later than two (2) Working Days before the Proposal Due Date, in each case by written notice through the Portal. A Proposal received after the time stated in Clause 6.1, and a modification received after the time stated in this Clause, will be rejected unopened and returned to the Bidder.’

- 2.2 The number 6.7 is not reused. The Clauses of Volume I are not renumbered.

3. AVAILABILITY PAYMENT AND INDEXATION

- 3.1 In Volume V Clause 1.1, ‘the annual payment calculated under Clause 29’ is deleted and **‘the annual payment, expressed at Base Date prices, calculated under Clause 29’** is substituted.
- 3.2 The following new Clause 1.1A is inserted in Volume V after Clause 1.1:
‘1.1A Base Date means the date falling twenty-eight (28) days before the Proposal Due Date.’
- 3.3 Volume V Clause 29.2 is deleted and replaced by the following:
‘29.2 The Availability Payment shall be indexed annually from the Base Date in accordance with Schedule 9. The proportion of the payment indexed to the published consumer price index (the Indexed Proportion) shall be: (a) until the end of the tenth (10th) year of operations, the percentage stated by the Bidder in Form 4-F, which shall be not less than fifty per cent (50%) and not more than seventy per cent (70%); and (b) from the start of the eleventh (11th) year of operations, seventy-five per cent (75%). The balance of the payment shall remain fixed.’
- 3.4 Bidders shall reflect this Section 3 in the Financial Model submitted under Volume I Clause 10.3.

4. MEMBRANE FILTRATION

4.1 In Volume II Clause 3.1, ‘The Authority does not mandate a particular process train.’ is deleted and **‘The treatment process shall include a membrane filtration step, either in the tertiary treatment stage or as part of a membrane bioreactor, with a nominal pore size not exceeding 0.1 µm. Subject to the preceding sentence, the Authority does not mandate a particular process train.’** is substituted.

4.2 Bidders shall reflect this Section 4 in the process design submitted under Volume II Section 3.

5. ODOUR CONTROL

5.1 In Volume II Clause 3.4, ‘not more than 5 OU/m³ at the site boundary’ is deleted and **‘not more than the odour concentration shown for the nearest sensitive receptor in Figure 7-2 of the Environmental and Social Impact Assessment referred to in Volume II Clause 9.1, at that receptor’** is substituted. The basis of assessment (98th percentile hourly value) is unchanged.

5.2 Bidders shall demonstrate compliance with Volume II Clause 3.4, as amended, in the Technical Proposal.

6. RESPONSES TO CLARIFICATION REQUESTS 15 TO 21

No	Bidder question	Authority response
15	Volume II Clause 6.4 requires process data to be retained for not less than seven (7) years. Would a retention period of ten (10) years be acceptable?	Volume II Clause 6.4 states a minimum period. A Bidder may propose a longer period but is not required to do so.
16	May a Bidder state ‘no deviations’ in Form 4-E and set out its assumptions on Volume V in the Technical Proposal?	A Bidder that states ‘no deviations’ in Form 4-E shall not include any qualification of Volume V elsewhere in its Proposal. An assumption that limits or qualifies an obligation in Volume V is a qualification and shall be listed in Form 4-E. Volume I Clause 9.6 applies.
17	Where the proposed EPC Contractor is an unincorporated joint venture, which entity must hold the ISO 9001:2015 certificate required by Volume I Clause 8.3?	Each member of the joint venture shall hold a certificate that meets Volume I Clause 8.3, and a copy of each certificate shall be submitted with Envelope A.
18	Will the Authority provide dispersion modelling inputs for the design of the odour control system?	The nearest sensitive receptor, and the odour concentration applicable at it for the purposes of Volume II Clause 3.4 as amended by Section 5 of this Addendum, are shown in Figure 7-2 of the Environmental and Social Impact Assessment, which is available to Bidders in the data room. No other modelling inputs will be provided.
19	Form 4-F requests the Availability Payment for year 1 of operations. Is that figure to be stated in the prices of year 1 of operations?	Yes. The Availability Payment stated in Form 4-F is the amount payable for year 1 of operations, in the prices of that year. Indexation under Volume V Clause 29.2 applies from the first anniversary of PCOD.
20	Form 4-F states ‘Per Volume V Clause 29.2’ against ‘Indexation basis assumed’. Is any figure to be stated in that row?	Yes. The Bidder shall complete that row by stating, after the words ‘Per Volume V Clause 29.2’, the Indexed Proportion as a percentage. The Indexed Proportion shall not be stated anywhere in Envelope A. Volume I Clause 6.2 applies.
21	Does the Technical Proposal need to address construction plant in addition to the matters listed in Volume I Clause 9.7?	Yes. The construction methodology in the Technical Proposal shall include a crane and lifting plan that demonstrates compliance with Table 5-1 (Volume II Clause 5.6, inserted by Section 7 of this Addendum).

7. HEIGHT OF STRUCTURES

7.1 The following new Clause 5.6 is inserted in Volume II after Clause 5.5:

‘5.6 The Project Company shall comply with the height limits in Table 5-1, which is reproduced at Appendix A to this Addendum as issued by the Northern Region Airspace Safeguarding Office and is incorporated into this Volume by reference.’

- 7.2 Table 5-1 is issued in the Arabic language. The Arabic text governs. The English translation at Appendix B is provided for convenience only.
- 7.3 A Bidder whose Proposal provides for any structure, plant or equipment at the site exceeding thirty (30) metres in height shall notify the Authority through the Portal, not later than three (3) Working Days before the Proposal Due Date, of the zone of Table 5-1 in which it is to be located and its proposed height.
- 7.4 Bidders shall reflect Table 5-1 in the Technical Proposal.

FICTIONAL — ASSESSMENT PACK

APPENDIX A — TABLE 5-1 (ARABIC)

Table 5-1 is reproduced below as issued by the Northern Region Airspace Safeguarding Office. The Arabic text governs in accordance with Section 7 of this Addendum.

Northern Region Airspace Safeguarding Office

مكتب حماية المجال الجوي بالمنطقة الشمالية

التاريخ: ١٠ نوفمبر ٢٠٢٦ م

الرقم: ٤٧١/٢٠٢٦

الموضوع: اشتراطات الارتفاعات لموقع محطة معالجة مياه الصرف الصحي المستقلة بوادي السرحان
مناقصة رقم: NUPA/ISTP/2026/014

جدول ١-٥: الحد الأقصى لارتفاع المنشآت والمعدات في الموقع


يُحدّد الحد الأقصى المسموح به للارتفاع في كل منطقة من مناطق الموقع على النحو الآتي:

المنطقة	الوصف	الحد الأقصى للارتفاع (متر فوق منسوب الأرض الطبيعية)	الإنارة التحذيرية
أ	الجزء من الموقع الواقع ضمن مسافة ١٥٠٠ متر من الحد الشرقي للموقع	٢٥	مطلوبة
ب	باقي مساحة الموقع	٤٠	مطلوبة لأي جزء يزيد ارتفاعه على ٣٠ متراً

ملاحظات:

١. تسري هذه الحدود على جميع المنشآت الدائمة والمؤقتة، بما في ذلك المداخل والرافعات ومعدات الإنشاء.
٢. يُقاس الارتفاع من منسوب الأرض الطبيعية قبل أعمال التسوية والردم.
٣. يجب إخطار المكتب قبل ثلاثين (٣٠) يوماً على الأقل من تركيب أي رافعة في الموقع.

مدير المكتب

End of reproduction.

APPENDIX B — ENGLISH TRANSLATION OF TABLE 5-1

This translation is provided for convenience only. The Arabic text of Table 5-1 at Appendix A governs.

Table 5-1 — Maximum height of structures and equipment at the site

Zone	Description	Maximum height (m above finished ground level)	Obstacle lighting
A	The part of the site within 1,500 m of the eastern site boundary	25	Required
B	The remainder of the site	40	Required for any part exceeding 30 m

Notes to Table 5-1:

- (1) These limits apply to all permanent structures, including stacks.
- (2) Height is measured from finished ground level after grading and filling.
- (3) The Office shall be notified at least thirty (30) days before any crane is erected at the site.