

ADDENDUM NO. 3

Issued 17 November 2026
Tender NUPA/ISTP/2026/014

Wadi Sirhan Independent Sewage Treatment Plant

This Addendum reduces the threshold in Volume V Clause 36.2 for compensation for a General Change in Law to SAR 4,000,000, relocates the handback condition survey from Volume II to Volume V, replaces the remaining design life required at handback with minimum residual service lives for four asset classes set out in Table 42-1 (issued in Arabic), invites Bidders to describe in their Technical Proposals how their lifecycle plans address Table 42-1, inserts a new Volume V Clause 12.5 on adverse ground conditions and requires Bidders to state the ground conditions assumed for the design of foundations, provides for the inspection of borehole cores and laboratory records with a limited exception to Volume I Clause 4.2, and responds to clarification requests 15 to 19.

This Addendum forms part of the RFP Documents and takes precedence in accordance with Volume I Clause 3.2. Bidders shall acknowledge receipt in Form 4-A. All other terms of the RFP Documents remain unchanged.

1. RECITALS

- 1.1 This Addendum is issued under Volume I Clause 5.3 and takes precedence over Addenda Nos. 1 and 2 in accordance with Volume I Clause 3.2.
- 1.2 A reference in this Addendum to a Clause, Table or Form is to that Clause, Table or Form as amended by Addenda Nos. 1 and 2, unless otherwise stated.
- 1.3 Clarification requests 15 to 19 were received before the time stated in Volume I Clause 5.2.

2. CHANGE IN LAW

- 2.1 The amount stated in Volume V Clause 36.2 is reduced by SAR 1,000,000.
- 2.2 Bidders shall take Section 2.1 into account in the Availability Payment quoted in Form 4-F.

3. HANDBACK

- 3.1 Volume II Clause 8.5 is relocated to Volume V, in which it becomes Clause 42.3. Its text is unchanged and reads as follows:

‘**42.3** A handback condition survey shall be carried out in the final two (2) years of the concession, and any remedial works identified shall be completed before transfer.’
- 3.2 The number 8.5 is not reused in Volume II, and the Clauses of Volume II are not renumbered.
- 3.3 In Volume V Clause 42.1, ‘Volume II Clause 8.5’ is deleted and ‘**Clause 42.3**’ is substituted.
- 3.4 In Volume V Clause 42.1, ‘with a remaining design life of not less than five (5) years for all major assets’ is deleted and ‘**with a residual service life, for each asset class, of not less than that stated in Table 42-1**’ is substituted. Table 42-1 is reproduced at Appendix A to this Addendum and forms part of Volume V.
- 3.5 Table 42-1 is issued in the Arabic language. The Arabic text governs. The English translation at Appendix B is provided for convenience only.
- 3.6 The Bidder shall demonstrate in the Technical Proposal how its lifecycle plan achieves the residual service lives in Table 42-1.

4. GROUND CONDITIONS

4.1 The following new Clause 12.5 is inserted in Volume V after Clause 12.4:

‘12.5 If the Project Company encounters at the site ground conditions that are materially more adverse than those described in the Geotechnical Baseline Report, it shall be entitled to an extension of the Scheduled PCOD and to payment of its reasonable additional costs, provided that it notifies the Authority within five (5) Working Days of encountering them. In this Clause, the Geotechnical Baseline Report means Revision C of the report of that name issued by the Authority.’

4.2 Each Bidder shall state in the Technical Proposal the ground conditions assumed for the design of foundations, by reference to the Geotechnical Baseline Report.

4.3 A Bidder that wishes to inspect the borehole cores and laboratory records on which the Geotechnical Baseline Report is based shall request an appointment through the Portal within three (3) Working Days of the date of this Addendum. Appointments will be held at the Authority's core store in Sakaka not later than three (3) Working Days before the Proposal Due Date.

4.4 Volume I Clause 4.2 does not apply to communications with the Authority's geotechnical consultant during an appointment under Section 4.3, to the extent that they concern the identification and handling of cores and records.

5. RESPONSES TO CLARIFICATION REQUESTS 15 TO 19

No	Bidder question	Authority response
15	Will the minutes of the Pre-Bid Conference at Appendix B to Addendum No. 1 be issued in Arabic?	No. The minutes are issued in English only. Section 3.2 of Addendum No. 1 continues to apply to them.
16	At what stage must the grievance mechanism referred to in Volume II Clause 9.3 be in place?	The grievance mechanism shall be established before construction, shall be accessible to the affected community and shall be maintained for the concession period. Volume II Clause 9.3 applies.
17	Volume I Clause 10.1 states that no document other than Form 4-F and the Financial Model shall be placed in Envelope B, but Volume I Clause 10.6 requires a schedule of financing assumptions to be submitted with Form 4-F. Where is the schedule to be placed?	The schedule required by Volume I Clause 10.6 forms part of Form 4-F and shall be attached to it in Envelope B. The schedule shall also state the minimum annual debt service cover ratio assumed. A schedule placed in Envelope A will be treated in accordance with Volume I Clause 6.2.
18	Volume V Clause 39.5 refers to a Direct Agreement with the Senior Lenders. If the Direct Agreement provides for compensation on termination for Project Company default that differs from Volume V Clause 40.2, which prevails?	The Authority notes the question. The order of precedence at Volume I Clause 3.2 applies. The Direct Agreement will be negotiated with the Senior Lenders after the Preferred Bidder Notification.
19	May Bidders inspect the borehole cores and laboratory records from the site investigation?	Yes, by appointment. Section 4.3 of this Addendum applies. Requests made after the period stated in that Section will not be accommodated.

APPENDIX A — TABLE 42-1 (ARABIC)

The following table is reproduced as issued by the Authority's Asset Transfer Committee under cover of its letter No. 417/2026 dated 15 November 2026. The Arabic text governs in accordance with Section 3.5 of this Addendum.

Northern Utilities Procurement Authority - Asset Transfer Committee

الهيئة الشمالية للمشتريات المرفقية

لجنة نقل الأصول

التاريخ: ١٥ نوفمبر ٢٠٢٦ م

الرقم: ٤١٧/٢٠٢٦

الموضوع: متطلبات حالة الأصول عند نقل محطة معالجة مياه الصرف الصحي المستقلة بوادي السرحان
مناقصة رقم: NUPA/ISTP/2026/014

جدول ٤٢-١: الحد الأدنى للعمر المتبقي للأصول عند النقل

يجب ألا يقل العمر المتبقي لكل فئة من فئات الأصول في تاريخ نقل المرفق إلى الهيئة عما هو مبين أدناه:

م	فئة الأصول	الحد الأدنى للعمر المتبقي (سنة)	أقصى درجة للحالة
١	المنشآت المدنية والخرسانية	٢٠	٢
٢	خط نقل المياه المعالجة	٢٠	٢
٣	المعدات الميكانيكية	٥	٣
٤	المعدات الكهربائية وأجهزة القياس والتحكم	٧	٣
٥	الأغشية (إن وجدت)	٢٤ شهراً	٣

ملاحظات:

١. تُقيّم درجة الحالة وفق مقياس الهيئة لتصنيف حالة الأصول المكوّن من خمس درجات، وتعني الدرجة ١ أن الأصل بحالة جديدة.
٢. يحدّد المهندس المستقل العمر المتبقي لكل أصل في مسح الحالة الذي يُجرى قبل النقل.
٣. يُستبدل على نفقة شركة المشروع قبل تاريخ النقل كل أصل لا يستوفي متطلبات هذا الجدول.

رئيس لجنة نقل الأصول

FICTIONAL DOCUMENT - Lamar Holding internal assessment pack - not a real tender.

End of reproduction.

APPENDIX B — ENGLISH TRANSLATION OF TABLE 42-1

This translation is provided for convenience only. The Arabic text of Table 42-1 at Appendix A governs. Asset Transfer Committee letter No. 417/2026 dated 15 November 2026. Subject: asset condition requirements on transfer of the Wadi Sirhan Independent Sewage Treatment Plant. Tender No. NUPA/ISTP/2026/014.

Table 42-1 — Minimum residual service life of assets at transfer

The residual service life of each asset class at the date of transfer of the Facility to the Authority shall be not less than stated below.

No	Asset class	Minimum residual life (years)	Maximum condition grade
1	Civil and concrete structures	20	2
2	Treated effluent transmission main	20	2
3	Mechanical equipment	5	3
4	Electrical, instrumentation and control equipment	5	3
5	Membranes (where provided)	24	3

Notes to Table 42-1:

- (1) Condition grade is assessed on the Authority's five-point asset condition grading scale, grade 1 meaning as new.
- (2) The Independent Engineer determines the residual service life of each asset in the condition survey carried out before transfer.
- (3) Any asset that does not meet this Table shall be replaced at the Project Company's cost before the date of transfer.
- (4) The design life of electrical equipment stated in Volume II Clause 2.2 is increased to twenty-five (25) years.

Signed: Chairman, Asset Transfer Committee, Northern Utilities Procurement Authority (signature and stamp).