



Unit 30 | Fern Close | Pen-Y-Fan Ind Est | Oakdale | Gwent | NP11 3EH | UK
Tel: +44 (0) 1495 236260 wales@nsf.org | www.nsf.org

TEST REPORT

Customer: C0791771

DOSITA HAVUZ VE SU TEKNOL OJILERI LTD. STI
Çiftlik Mah
Bilgin caddesi
no 14 Gölçük
Türkiye

Result	PASS	Report Date	28-MAY-2024
Customer Name	DOSITA HAVUZ VE SU TEKNOL OJILERI LTD. STI		
Section Number	2415		
Test Type	First Application		
Job Number	J-00491240		
Work Order Number	W0903649		
Manufacturing Status	Production		
Account Manager	Ethan Martin		

Thank you for having your product tested by NSF Wales Ltd.

Please contact your Account Manager if you have any questions or concerns pertaining to this report.

Report Date 28-MAY-2024

Report Authorisation

Cian Broad - Senior Technician Labs Wales





Sample ID: S-0002099767

Model Number /Trade Designation: Ionsafe 1

Analysis	Result
TCS 6001.1 (A) (Issue 7) Marking for Identification (All fittings) (Proc. 18703)	Pass
TCS 1412.1 (Issue 3) Corrosion protection. (Proc. 18593)	Pass
TCS 5011.1 (Issue 3) Measurement of linear dimensions (Proc. 18688)	Pass
TCS 1112.1 (N) (Issue 3) Porosity – All Other Valves-Fittings (Proc. 28705)	Pass
TCS 1113.1 (F) (Issue 3) Joint Effectiveness – All Other Valves & Fittings (Proc. 28708)	Pass
TCS 2114.2 (Issue 4) Opacity (Proc. 18632)	Not Applicable

Sample ID: S-0002099767
Sample Name: Ionsafe 1
Sample Description: Water disinfection unit based on copper silver electrodes and electrolysis.
Sample Received: 26-MAR-2024

Product Type: Disinfection system
Model Number/Trade Designation: Ionsafe 1
Maximum Working Pressure: 9 Bar
Maximum Operating Temperature: 75 deg C

<< Results >>

† TCS 4001.11 (Issue 1) Visual inspection (Proc. 18685) (WP1397)

Technician ID	NGORDON
Date Analysed	26-03-2024
Visual Confirmation of Sample	Does / do the samples submitted for testing visually conform (without dismantling) to the product(s) that were identified as representative of the range for which approval is sought?
Visual Confirmation of Sample Result	Yes
Confirmation of Sub Components	Does / do the individually declared sub-component(s) used in the sample submitted for testing appear to be those that were declared in the application?
Confirmation of Sub Components Result	Yes

TCS 6001.1 (A) (Issue 7) Marking for Identification (All fittings) (Proc. 18703) (WP1355)

Technician ID	DHOWELL
Date Analysed	22-05-2024
Product Marking and location	Dosita name on dataplate on control box
TCS Clause (A, A+B, A+C, A+D, A+E, A+F)	A
Permanence of Marking	Yes
Marking for Identification (P/F)	Pass

TCS 1412.1 (Issue 3) Corrosion protection. (Proc. 18593) (WP1343)

Technician ID	DHOWELL
Date Analysed	22-05-2024
List Metals in Contact	Stainless Steel, Copper, Silver
Coating Irregularities (None Req'd)	None
Electrochem Test Result	Pass

TCS 2111.1 (Issue 3) Effect upon water quality (non-metallic materials) (Proc. 18629) (WP1385)

Technician ID	DHOWELL
Date Analysed	22-05-2024
Non Metallic Materials	Verified by Account Manager

TCS 5011.1 (Issue 3) Measurement of linear dimensions (Proc. 18688) (WP1354)

TCS 5011.1 (Issue 3) Measurement of linear dimensions (Proc. 18688) (WP1354) (Continued)

Technician ID	DHOWELL
Date Analysed	22-05-2024
Linear Dimensions	2" BSP M
Linear Dimension Result (P/F)	Pass

TCS 1112.1 (N) (Issue 3) Porosity – All Other Valves-Fittings (Proc. 28705) (WP1368)

Technician ID	DHOWELL
Date Analysed	22-05-2024
Temperature (20 ± 10 deg C)	18.3 deg C
Above or Below Ground Use	Above Ground
Pressure Rating (PN)	9 bar
Pressure multiplier	x 1.5
Required Test Pressure	13.5 bar
Test pressure limits	± 0.5 Bar
Actual test pressure	13.5 bar
Hydraulic Pressure Duration (60 ± 5 sec)	60 sec
Leakage (None)	None
Porosity Test - (P/F)	Pass

TCS 1113.1 (F) (Issue 3) Joint Effectiveness – All Other Valves & Fittings (Proc. 28708) (WP1373)

Technician ID	DHOWELL
Date Analysed	22-05-2024
temperature (20 ± 10 deg C)	18.3 deg C
Above or Below Ground Use	Above Ground
Maximum Hydraulic Water Pressure (PN)	9 bar
Pressure multiplier	x 1.5
Required Test Pressure	13.5 bar
Test pressure limits	± 0.5 Bar
Actual Hydraulic Water Pressure	13.5 bar
Raise time (> 30 sec)	30sec
Hydraulic pressure duration (15 ± 1 min)	15 min
Leakage (None)	None
Joint Effectiveness Test - (P/F)	Pass

TCS 2114.2 (Issue 4) Opacity (Proc. 18632) (WP1349)

Technician ID	DHOWELL
Date Analysed	22-05-2024
Opacity test result - P/F	Not Applicable
comment	Metal

<< Testing Laboratories >>

	Flag	Id	Address
All work performed at: (Unless otherwise specified)	→	NSF_WALES	NSF Wales Ltd. NSF Wales Ltd Unit 30 Fern Close Pen-Y-Fan Industrial Estate Oakdale, Newport NP11 3EH, UK

NOTES

1. This report is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service (UKAS). NSF Wales Ltd is UKAS accredited against ISO/IEC 17025:2017 for testing, laboratory number 0626. For details of the laboratory Schedule of Accreditation please see the UKAS website (www.ukas.com).
2. It provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes.
3. The contents of this report are the copyright of NSF Wales Ltd and all rights are reserved. No part of this publication may be reproduced, stored in a retrieval system in any form or by any means electronic, mechanical, photocopying, recording or otherwise, without prior written consent of NSF Wales Ltd.
4. This test report does not constitute approval or endorsement of the product by either NSF Wales Ltd or its parent companies.
5. Any queries regarding this report should be addressed to the authorised signatory at NSF Wales Ltd. Copies of reports are retained by NSF Wales Ltd for ten years after issue.
6. The results specified in this report relate only to the sample(s) of the product submitted for testing. Any change in the source or nature of the product or materials used in the product, method of manufacture or application could affect the performance of the product.
7. Where tests are static and rely on a single measurand, any statements of conformity will be non-binary and will be based on guard banded acceptance (ref: ILAC-G8:09-2019 4.2.3) which takes into account the estimated uncertainty of measurement. Measured results within the guard band but below the tolerance limit will be reported as a conditional pass whilst results within the guard band but outside the tolerance limit will be reported as a conditional fail. Measured results outside the guard band will be reported as pass or fail as appropriate. The risk of results reported as pass to be outside the tolerance limit or for results reported as fail to be inside the tolerance limit is < 2.5%.
8. Where tests are dynamic and rely on a number of disparate input variables each with tolerances defined in the specification for the test, statements of conformity will be binary and based on a simple acceptance rule (ref: ILAC-G8:09-2019 4.2.1). Statements of conformity will be reported as pass or fail based on the measured value without taking measurement uncertainty into account. Uncertainty of measurement for the instrumentation used for each measured value will be reported alongside the individual measurements. The risk of measured results reported as pass or fail being outside the tolerance limit is 50%.
9. Where an expanded uncertainty is reported for a test, this will be based on a standard uncertainty multiplied by a coverage factor $k = 2$, providing a level of confidence of approximately 95%. The expanded uncertainty will have been carried out in accordance with UKAS requirements.
10. Test reports utilise the simplified test report format option allowed by ISO/IEC 17025:2017 (reference clause 7.8.1.3). This simplified report does not include all of the information on the report specified by ISO/IEC 17025:2017 (clauses 7.8.2 to 7.8.7) but as stated in the standard this data is held by the laboratory and is available to the client on request.
11. Opinions and interpretations in this report are outside the scope of UKAS Accreditation.
12. Non UKAS accredited tests or tests which have been subcontracted will be identified in the following manner:
 - Tests marked † are not included in the laboratory's ISO 17025 accreditation schedule.
 - Tests marked ± have not been performed by NSF Wales Ltd and have been performed at an approved subcontract laboratory.
13. All work is performed at NSF Wales Ltd laboratory, 30 Fern Close, Pen-Y-Fan Ind Est, Oakdale NP11 3EH, unless otherwise specified in accordance with point 12 above.