CNT Material Approval Request Form (MAR)

Submittal Ref.	**01101-SAC-MAT-ARC-000038**	**Revision**	**00**	**Date**	**17-11-2025**
Project Title	**AL MANAR PROJECT - PHASE 1 SINGLE FAMILY & PUBLIC AMENITIES BUILDING WORK**				
Call of Order No:	**PO-RRE-4255**				
Client	**ROSHN Real Estate Company**				
Engineer/Consultant	**Hill International**				
Contractor	**SARH ATTAQNIA CO. (SAC)**				

Discipline:	☐ Civil ☒ Architecture ☐ Mechanical ☐ Electrical ☐ Geotechnical ☐ General

Subject:	**Block & Plaster Accessories - Modern Metal Industries Co. – MMICO**
Specs. / BOQ / Drawings Reference:	**Revised to Value Engineering & BOQ**
Material Description Alternative Material Request:	☒ Datasheet ☐ Catalogue ☒ Certificate ☐ Sample ☒ Test result ☒ Others
Manufacturer / Local Supplier Name:	Name: Modern Metal Industries Co. – MMICO Country Of Origin: KSA Local Agent: Modern Metal Industries Co. – MMICO
Delivery Availability	☒ Local ☐ Overseas
Remarks:	

Contractor Signatures & Stamp:

QA-QC Engineer	QA-QC Manager		
Maher	Fawzy Mansour	Date:	17-11-2025

Received By CSC Engineer:

Name	Name	Signature		Date/ Time	

Final Submittal Status:

☐ A- Approved ☑ B- Approved As Noted ☐ C- Revise and Re-submit ☐ D- Rejected

Engineer's Comments:

1. Facade grooves must be maintained properly as per design, or otherwise, the Contractor should arrange a special accessory.
2. The recommended plaster stop bead, if required, is 19mm plaster depth.
3. The Contractor should use the Manufacturer's recommended bolts for fixing the accessories.
4. The Contractor should submit the Samples for the Engineer's approval.
5. Sustainability:The contractor shall provide a recycled content letter confirming the recycled materials used in the plastering and block accessories if available.
6. Sustainability: The contractor shall also complete and attach the corresponding SQM form for this MAT.

Workflow Action	Name	Signature	Date
Reviewed by (Engineer)			
Approved by (Engineer)	Wisam Alani		22/11/2025
Received By (Contractor)			
Distribution:			
☐ Engineer	☐ Contractor	☐ Others (Specify)	Distribute to:

CNT Document Submittal Form

Submittal Ref	**01101-SAC-PQL-ARC-000025**	**Revision**	**00**	**Date/Time**	**26-10-2025**
Project:	**AL MANAR PROJECT - PHASE 1 SINGLE FAMILY & PUBLIC AMENITIES BUILDING WORKS**				
Call of Order No:	**PO-RRE-4255**				
Client	**ROSHN Real Estate Company**				
Engineer/Consultant	**Hill International**				
Contractor	**SARH ATTAQNIA CO. (SAC)**				
Discipline:	☐ Civil ☒ Architecture ☐ Mechanical ☐ Electrical ☐ Geotechnical (GEO) ☐ General				
Document type:	☐ MST ☒ PQD ☐ RECORD ☐ SHD ☐ REPORTS ☐ Others				
Doc Add Type/ Sub Type (If Any):	☐				

Documents Details:

SN.NO.	Document Title/ Description	Reference No.	Rev. No.	Media (Elect. /Hard)	No. of Copies
1	**Modern Metal Industries Company (Manufacturer & Supplier) for Block and Plaster Accessories Brand - MMICO**	**01101-SAC-PQL-ARC-000025**	**00**	PM-Web	01

Contractor Signatures & Stamp:

QC Engineer			**QA-QC Manager**				
Eng. Maher	**Signature**		**Eng. Fawzy**	**Signature**		**Date**	**26-10-2025**

Received By CSC Engineer:

Name		**Signature**		**Date/ Time**	

Submittal Status:

☐ A- Approved ☑ B- Approved As Noted ☐ C- Revise and Re-submit ☐ D- Rejected

Engineer's Comments:

The GOSI certificate shall to be provided, and all other certificates must remain valid throughout the project duration and be updated in timely manner.

Workflow Action	Name	Signature	Date
Reviewed by (Engineer)	Arif Hussain		30-10-2025
Approved by (Engineer)	Mostafa Gad		30 Oct 2025
Received By (Contractor)			

Distribution:

☐ Engineer	☐ Contractor	☐ Others (Specify)	.....