Submittal item detail

#P146-BSCC-MT-09DP-AR-058-0: Material Submittal and Data Sheet for Block & Plastering Accessories-Modern Metal Industries Company

Status	Created on	Ball in court due date
Open Reviewed	Sep 26, 2026	

ID	971
Ball in court	**Ahmed Abdul-ghany** (AMEC)
Manager	**Ahmed Abdul-ghany** (AMEC)
Responsible contractor	**Tarek Elabassy** (BSCC)
Watchers	**Adil Qanawi** (AMEC) **ahmed eldaabosy** (Almajid) **Ahmed Mustafa** (OSUS) **Ali Javed** (Almajid) **mibrahim mibrahim** (Almajid)
Spec section	013300 Submittal Procedures
Spec sub section	
Type	Material Approval Request_AR
Description	Material Submittal and Data Sheet for Block & Plastering Accessories-Modern Metal Industries Company
Final Response	
Final Response Attachments	
Final Response Comments	
Package	

Rev 0

Ball in court	Sent	Due	Returned	Response/Action	Attachments
Submitted					
Tarek Elabassy (BSCC)	-	-	Sep 26, 2026	**Submitted**	Material_Approval_Request_MMICO_Organized.pdf
Comments	-				
Sent for review					
Ahmed Abdul-ghany (AMEC) Sent by Ahmed Abdul-ghany	Sep 26, 2026	-	-	**Sent for review**	
Comments	-				
Review Step 1					
mohamed atif khalil (AMEC) Reviewed By mohamed atif khalil	Sep 27, 2026	Oct 2, 2026	Oct 6, 2026	**B- Approved as noted**	
Comments	No objection to the approval of Modern Metal Industries Company as a supplier of Block & Plastering Accessories, subject to compliance with the following requirements: All required certificates and approvals shall remain valid throughout the project duration, and the National Address shall be updated, with the updated document submitted accordingly. Submit Certificates of Conformity issued by the Saudi Standards, Metrology and Quality Organization (SASO) or equivalent, in accordance with the requirements of the Authority. Submit test certificates issued by an accredited laboratory to verify the tensile strength of the materials. All products shall be manufactured from Galvanized Steel, including nails and fixing/fastening accessories. The width of the Expanded Metal Lath shall not be less than 200 mm (20 cm). The Corrugated Angle shall be 30 mm (3 cm) wide and shall have a length of not less than 200 mm (20 cm). All materials shall be in compliance with the approved project technical specifications. The final				

Rev 0

Ball in court	Sent	Due	Returned	Response/Action	Attachments
	approval shall be conditional upon full compliance with all the above requirements. Such approval shall not relieve the Contractor of his full responsibility for the proper supply, installation, protection, handling, and storage of the materials. All required material samples shall be submitted in full, properly stored, identified, and documented in the Sample Room, in accordance with the approved project procedures.				